SWIMMING POOL OFFICIAL INSPECTION REPORT

GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988
Phone: (530) 934-6102 • Fax: (530) 934-6103

Name of Facility/DBA: Orland Municipal Wading Pool	Inspection Date: 6/20/16
Address: 815 Fourth St, Orland, CA 95963	Reinspection Date (on or after): ~~Next Inspection~~ By Appt (Reinspections are subject to fees)
Owner/Permittee: City of Orland	Phone Number: 865-1631
Inspection Time: 2:00 pm	Permit Expiration Date:
Pool Type: ☐ Swimming Pool ☐ Spa Pool ☒ Wading Pool ☐ Interactive Water Feature ☐ Other	Service: ☒ Routine Inspection ☐ Reinspection ☐ Complaint ☐ Construction/Pre-Opening ☐ Other

pH:	Free Chlorine:	Combined Chlorine:	Cyanuric Acid:	Flow Rate:	Temperature:	Other:
7.5	2.1 ppm	2.4 ppm	22 ppm	unknown	–	Total Alk - 115 ppm CA Hard - 54 ppm

Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20

Pool Construction
1. ☐ Pool Shell
2. ☐ Bottom & Sides
3. ☐ Decks & Coping
4. ☐ Diving Boards
5. ☐ Depth Markers
6. ☐ Ladders/Steps/Railings
7. ☐ Underwater Lighting & Electrical

Recirculation Equipment
8. ☐ Filters
9. ☐ Pumps
10. ☒ Flowmeter
11. ☐ Pressure/Vacuum Gauges
12. ☒ Skimmers & Gutters
13. ☐ Pipes & Fittings
14. ☐ Chemical Feeders
15. ☐ Water Supply/Backflow Prevention

Water Quality
16. ☐ pH
17. ☒ Chlorine/Bromine
18. ☐ Cyanuric Acid
19. ☐ Debris in Pool
20. ☐ Water Clarity
21. ☐ Temperature
22. ☐ Flow Rate/Turnover

Safety Equipment
23. ☐ Gates/Enclosure
24. ☐ Drain Covers
25. ☐ Anti-Entrapment Shutoff
26. ☐ Rescue Pole
27. ☐ Life Ring
28. ☐ Safety Signs
29. ☐ First Aid Kit
30. ☐ Chlorine Gas Safety

General Facilities
31. ☐ Exterior Lighting
32. ☐ Indoor Ventilation
33. ☐ Restrooms & Toilets
34. ☐ Handwash Sinks
35. ☐ Dressing Rooms
36. ☐ Showers
37. ☐ Drinking Fountains

Miscellaneous
38. ☐ Chemical Test Kits
39. ☐ Chemical Testing Frequency
40. ☐ Record Keeping
41. ☐ Lifeguards
42. ☐ Communicable Disease Control
43. ☐ Site Supervision & Control
44. ☐ General Sanitation
45. ☐ Other:

Comments:

* Wading Pool is closed due to inadequate free chlorine. Do not reopen without approval from our department.

* Critical Violation (Closure Violation)

17) Provide 3.0-10.0 ppm of free available chlorine. Free chlorine measured 2.1 ppm.

Other Violations

10) Repair/replace inoperable flow meter.

12) Replace missing weir at west skimmer.

Received By: Austin Somers

REHS: John H. Wells

SWIMMING POOL OFFICIAL INSPECTION REPORT
GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988
Phone: (530) 934-6102 • Fax: (530) 934-6103

Name of Facility/DBA: Orland Municipal ~~Pool~~ Wading Pool	Inspection Date: 6/20/16
Address: 815 Fourth St, Orland, CA 95963	Reinspection Date (on or after): Next Inspection (Reinspections are subject to fees)
Owner/Permittee: City of Orland	Phone Number: 865-1631
Inspection Time: 3:30 pm	Permit Expiration Date:
Pool Type: ☒ Swimming Pool ☐ Spa Pool ☐ Wading Pool ☐ Interactive Water Feature ☐ Other	Service: ☐ Routine Inspection ☒ Reinspection ☐ Complaint ☐ Construction/Pre-Opening ☒ Other Reopening

pH:	Free Chlorine:	Combined Chlorine:	Cyanuric Acid:	Flow Rate:	Temperature:	Other:
	4-2 ppm					

Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20

Pool Construction
1. ☐ Pool Shell
2. ☐ Bottom & Sides
3. ☐ Decks & Coping
4. ☐ Diving Boards
5. ☐ Depth Markers
6. ☐ Ladders/Steps/Railings
7. ☐ Underwater Lighting & Electrical

Recirculation Equipment
8. ☐ Filters
9. ☐ Pumps
10. ☐ Flowmeter
11. ☐ Pressure/Vacuum Gauges
12. ☐ Skimmers & Gutters
13. ☐ Pipes & Fittings
14. ☐ Chemical Feeders
15. ☐ Water Supply/Backflow Prevention

Water Quality
16. ☐ pH
17. ☐ Chlorine
18. ☐ Cyanuric Acid
19. ☐ Other Chemicals
20. ☐ Water Clarity
21. ☐ Temperature
22. ☐ Flow Rate/Turnover

Safety Equipment
23. ☐ Gates/Enclosure
24. ☐ Drain Covers
25. ☐ Anti-Entrapment Shutoff
26. ☐ Rescue Pole
27. ☐ Life Ring
28. ☐ Safety Signs
29. ☐ First Aid Kit
30. ☐ Chlorine Gas Safety

General Facilities
31. ☐ Exterior Lighting
32. ☐ Indoor Ventilation
33. ☐ Restrooms & Toilets
34. ☐ Handwash Sinks
35. ☐ Dressing Rooms
36. ☐ Showers
37. ☐ Drinking Fountains

Miscellaneous
38. ☐ Chemical Test Kits
39. ☐ Chemical Testing Frequency
40. ☐ Record Keeping
41. ☐ Lifeguards
42. ☐ Communicable Disease Control
43. ☐ Site Supervision & Control
44. ☐ General Sanitation
45. ☐ Other:

Comments:
Recheck of chlorine closure violation from 6/20/16 at 2:00 pm found free chlorine measured 4-2 ppm.

* Pool is cleared to reopen.

Received By: [signature] REHS: John H. Wells

Revised July 23, 2014