# SWIMMING POOL OFFICIAL INSPECTION REPORT

## GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988
Phone: (530) 934-6102 • Fax: (530) 934-6103



| | | | |
|---|---|---|---|
| Name of Facility/DBA: Orland Municipal Wading Pool | | Inspection Date: 8/3/16 | |
| Address: Roosevelt Ave, Orland, CA 95963 | | Reinspection Date (on or after): By Appointment (Reinspections are subject to fees) | |
| Owner/Permittee: City of Orland | Phone Number: | Inspection Time: 3:15pm | Permit Expiration Date: |

Pool Type: ☐ Swimming Pool ☐ Spa Pool ☒ Wading Pool ☐ Interactive Water Feature ☐ Other

Service: ☐ Routine Inspection ☒ Reinspection ☐ Complaint ☐ Construction/Pre-Opening ☐ Other

| pH: | Free Chlorine: | Combined Chlorine: | Cyanuric Acid: | Flow Rate: | Temperature: | Other: |
|---|---|---|---|---|---|---|
| 7-2 | 2.0 ppm | 0.4 ppm | <10 ppm | | | |

*Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20*

**Pool Construction**
1. ☐ Pool Shell
2. ☐ Bottom & Sides
3. ☐ Decks & Coping
4. ☐ Diving Boards
5. ☐ Depth Markers
6. ☐ Ladders/Steps/Railings
7. ☐ Underwater Lighting & Electrical

**Recirculation Equipment**
8. ☐ Filters
9. ☐ Pumps
10. ☐ Flowmeter
11. ☐ Pressure/Vacuum Gauges
12. ☐ Skimmers & Gutters
13. ☐ Pipes & Fittings
14. ☐ Chemical Feeders
15. ☐ Water Supply/Backflow Prevention

**Water Quality**
16. ☐ pH
17. ☐ Chlorine/Bromine
18. ☐ Cyanuric Acid
19. ☐ Debris in Pool
20. ☐ Water Clarity
21. ☐ Temperature
22. ☐ Flow Rate/Turnover

**Safety Equipment**
23. ☐ Gates/Enclosure
24. ☐ Drain Covers
25. ☐ Anti-Entrapment Shutoff
26. ☐ Rescue Pole
27. ☐ Life Ring
28. ☐ Safety Signs
29. ☐ First Aid Kit
30. ☐ Chlorine Gas Safety

**General Facilities**
31. ☐ Exterior Lighting
32. ☐ Indoor Ventilation
33. ☐ Restrooms & Toilets
34. ☐ Handwash Sinks
35. ☐ Dressing Rooms
36. ☐ Showers
37. ☐ Drinking Fountains

**Miscellaneous**
38. ☐ Chemical Test Kits
39. ☐ Chemical Testing Frequency
40. ☐ Record Keeping
41. ☐ Lifeguards
42. ☐ Communicable Disease Control
43. ☐ Site Supervision & Control
44. ☐ General Sanitation
45. ☐ Other:

Comments:

Recheck found wading pool still less than 3.0 ppm of free chlorine. ~~Free~~ chlorine shall be between 3.0-10.0 ppm.

Wading pool shall remain closed until corrected.

Pool has been drained & supplied with fresh water after measuring over 200 ppm of chlorine on 8/2/16.

Received By: [signature]

REHS: John H. Wells

# SWIMMING POOL OFFICIAL INSPECTION REPORT

## GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988
Phone: (530) 934-6102 • Fax: (530) 934-6103



| | | | |
|---|---|---|---|
| Name of Facility/DBA: Orland Municipal Wading Pool | | | Inspection Date: 8/2/16 |
| Address: 815 Fourth St, Orland, CA 95963 | | | Reinspection Date (on or after): By Appointment (Reinspections are subject to fees) |
| Owner/Permittee: City of Orland | Phone Number: 865-1631 | Inspection Time: 3:00pm | Permit Expiration Date: |
| Pool Type: ☐ Swimming Pool ☐ Spa Pool ☒ Wading Pool ☐ Interactive Water Feature ☐ Other | Service: ☒ Routine Inspection ☐ Reinspection ☐ Complaint ☐ Construction/Pre-Opening ☐ Other | | |

| pH: | Free Chlorine: | Combined Chlorine: | Cyanuric Acid: | Flow Rate: | Temperature: | Other: |
|---|---|---|---|---|---|---|
| Not Tested | > 200 ppm | – | Not Tested | Could not determine | – | – |

*Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20*

**Pool Construction**
1. ☐ Pool Shell
2. ☐ Bottom & Sides
3. ☐ Decks & Coping
4. ☐ Diving Boards
5. ☐ Depth Markers
6. ☐ Ladders/Steps/Railings
7. ☐ Underwater Lighting & Electrical

**Recirculation Equipment**
8. ☐ Filters
9. ☐ Pumps
10. ☒ Flowmeter
11. ☐ Pressure/Vacuum Gauges
12. ☒ Skimmers & Gutters
13. ☐ Pipes & Fittings
14. ☐ Chemical Feeders
15. ☐ Water Supply/Backflow Prevention

**Water Quality**
16. ☐ pH
17. ☒ Chlorine/Bromine
18. ☐ Cyanuric Acid
19. ☐ Debris in Pool
20. ☐ Water Clarity
21. ☐ Temperature
22. ☐ Flow Rate/Turnover

**Safety Equipment**
23. ☐ Gates/Enclosure
24. ☐ Drain Covers
25. ☐ Anti-Entrapment Shutoff
26. ☐ Rescue Pole
27. ☐ Life Ring
28. ☐ Safety Signs
29. ☐ First Aid Kit
30. ☐ Chlorine Gas Safety

**General Facilities**
31. ☐ Exterior Lighting
32. ☐ Indoor Ventilation
33. ☐ Restrooms & Toilets
34. ☐ Handwash Sinks
35. ☐ Dressing Rooms
36. ☐ Showers
37. ☐ Drinking Fountains

**Miscellaneous**
38. ☐ Chemical Test Kits
39. ☐ Chemical Testing Frequency
40. ☐ Record Keeping
41. ☐ Lifeguards
42. ☐ Communicable Disease Control
43. ☐ Site Supervision & Control
44. ☐ General Sanitation
45. ☐ Other:

Comments:

* Wading pool is closed. Do not reopen without prior approval from our department.
* Operator had voluntarily closed wading pool prior to inspector's arrival at site.

* Critical Violation (Closure Violation)

17) Maintain free chlorine between 3.0 - 10.0 ppm. Measured over 200 ppm of chlorine using test strip. Operator was observed overchlorinating pool upon arrival.

Other Violations

10) Repair inoperable flow meter.
12) Replace missing weir at west skimmer.

Received By: X [signature] REHS: John H. Wells