

FOOD FACILITY INSPECTION REPORT

Continuation Sheet

GLENN COUNTY ENVIRONMENTAL HEALTH DEPARTMENT

247 North Villa Avenue, Willows, CA 95988
Phone (530) 934-6102 FAX (530) 934-6103

Page 2 of 2

| | |
|---|-----------------------------------|
| Name of Facility/ DBA: <u>BUBBA'S PLACE</u> | Inspection Date: <u>2/8/18</u> |
| Address: <u>PAGE 2</u> | |
| Owner/Permittee: <u>PAGE 2</u> | |
| Applicable Law CALIFORNIA RETAIL FOOD CODE ("CalCode), Beginning with section 113700, California Health and Safety Code | |

Comments: VIOLATIONS (CONT.)

(1) PROVIDE A PROPER AIR GAP FOR THE PLUMBING ON THE BAR 3-COMPARTMENT SINK TO PREVENT BACK SIPHONAGE.

(2) WALLS IN FOOD PREP AREAS MUST HAVE 4 INCHES OF COVING THAT IS INTEGRAL WITH THE FLOOR. FLOORING IS STILL MISSING COVING.

(3) FACILITY HAS REALLY STARTED EXPANDING FOOD SERVICE & ALL THE KITCHEN/PREP AREAS MUST BE PLAN CHECKED. CONTACT OUR OFFICE AND SUBMIT PLANS FOR THE FACILITY NEW FOOD SERVICE. BELOW IS A LIST (NOT COMPREHENSIVE) OF THINGS THAT NEED TO BE CHANGED:

- HAND SINK NEEDS TO BE INSTALLED
- PREP SINK NEEDS TO BE INSTALLED
- PROPERLY ^{SIZED} SUPPORTED 3-COMPARTMENT SINK NEEDS TO BE INSTALLED
- ALL NEW APPLIANCES MUST BE COMMERCIAL & PLAN CHECKED.
- WALLS AND FLOORS NEED TO BE BROUGHT UP TO CODE WITH F.R.P, COVING, ETC.

| | |
|----------------------------------|---------------------------|
| Received By: <u>Andrew Perry</u> | REHS: <u>Andrew Perry</u> |
|----------------------------------|---------------------------|