SWIMMING POOL OFFICIAL INSPECTION REPORT

GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988
Phone: (530) 934-6102 • Fax: (530) 934-6103

Name of Facility/DBA: Orland Municipal Wading Pool				Inspection Date: 7/31/15	
Address: 815 Fourth St, Orland, CA 95963				Reinspection Date (on or after): Next Inspection (Reinspections are subject to fees)	
Owner/Permittee: City of Orland		Phone Number: 865-1631		Inspection Time: 1:55 pm	Permit Expiration Date:
Pool Type: ☐ Swimming Pool ☐ Spa Pool ☒ Wading Pool ☐ Interactive Water Feature ☐ Other		Service: ☐ Routine Inspection ☒ Reinspection ☐ Complaint ☐ Construction/Pre-Opening ☐ Other			
pH: 7.1	Free Chlorine: 7.7 ppm	Combined Chlorine: 8.3 ppm	Cyanuric Acid: –	Flow Rate: –	Temperature: –	Other: –

Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20

Pool Construction	Water Quality	General Facilities
1. ☐ Pool Shell	16. ☐ pH	31. ☐ Exterior Lighting
2. ☐ Bottom & Sides	17. ☐ Chlorine	32. ☐ Indoor Ventilation
3. ☐ Decks & Coping	18. ☐ Cyanuric Acid	33. ☐ Restrooms & Toilets
4. ☐ Diving Boards	19. ☐ Other Chemicals	34. ☐ Handwash Sinks
5. ☐ Depth Markers	20. ☐ Water Clarity	35. ☐ Dressing Rooms
6. ☐ Ladders/Steps/Railings	21. ☐ Temperature	36. ☐ Showers
7. ☐ Underwater Lighting & Electrical	22. ☐ Flow Rate/Turnover	37. ☐ Drinking Fountains
Recirculation Equipment	**Safety Equipment**	**Miscellaneous**
8. ☐ Filters	23. ☐ Gates/Enclosure	38. ☐ Chemical Test Kits
9. ☐ Pumps	24. ☐ Drain Covers	39. ☐ Chemical Testing Frequency
10. ☐ Flowmeter	25. ☐ Anti-Entrapment Shutoff	40. ☐ Record Keeping
11. ☐ Pressure/Vacuum Gauges	26. ☐ Rescue Pole	41. ☐ Lifeguards
12. ☐ Skimmers & Gutters	27. ☐ Life Ring	42. ☐ Communicable Disease Control
13. ☐ Pipes & Fittings	28. ☐ Safety Signs	43. ☐ Site Supervision & Control
14. ☐ Chemical Feeders	29. ☐ First Aid Kit	44. ☐ General Sanitation
15. ☐ Water Supply/Backflow Prevention	30. ☐ Chlorine Gas Safety	45. ☐ Other:

Comments:

* Wading pool is cleared to reopen.

- chlorine in acceptable range (3-10 ppm)
- will check skimmer weir at next inspection

Received By: X [signature] REHS: John H. Wells