

# SWIMMING POOL OFFICIAL INSPECTION REPORT

## GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988  
Phone: (530) 934-6102 • Fax: (530) 934-6103

Name of Facility/DBA: <b>BEST WESTERN Willows Inn</b>		Inspection Date: <b>5/13/19</b>	
Address: <b>475 N. HUMBOLDT AVE, WILLOWS</b>		Reinspection Date (on or after):  (Reinspections are subject to fees)	
Owner/Permittee: <b>SARESH PATEL</b>	Phone Number: <b>934-4444</b>	Inspection Time: <b>4:00</b>	Permit Expiration Date:
Pool Type: <input checked="" type="checkbox"/> Swimming Pool <input type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other	Service: <input checked="" type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input checked="" type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other		
pH: <b>7.9</b>	Free Chlorine: <b>NON-DETECT</b>	Combined Chlorine: <b>N/A</b>	Cyanuric Acid: <b>~13 PPM</b>
Flow Rate: <b>65 GPM</b>	Temperature: <b>-</b>	Other:	

*Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20*

<b>Pool Construction</b> 1. <input type="checkbox"/> Pool Shell 2. <input type="checkbox"/> Bottom & Sides 3. <input type="checkbox"/> Decks & Coping 4. <input type="checkbox"/> Diving Boards 5. <input type="checkbox"/> Depth Markers 6. <input type="checkbox"/> Ladders/Steps/Railings 7. <input type="checkbox"/> Underwater Lighting & Electrical	<b>Water Quality</b> 16. <input checked="" type="checkbox"/> pH 17. <input checked="" type="checkbox"/> Chlorine/Bromine 18. <input type="checkbox"/> Cyanuric Acid 19. <input checked="" type="checkbox"/> Debris in Pool 20. <input type="checkbox"/> Water Clarity 21. <input type="checkbox"/> Temperature 22. <input type="checkbox"/> Flow Rate/Turnover	<b>General Facilities</b> 31. <input type="checkbox"/> Exterior Lighting 32. <input type="checkbox"/> Indoor Ventilation 33. <input type="checkbox"/> Restrooms & Toilets 34. <input type="checkbox"/> Handwash Sinks 35. <input type="checkbox"/> Dressing Rooms 36. <input type="checkbox"/> Showers 37. <input type="checkbox"/> Drinking Fountains
<b>Recirculation Equipment</b> 8. <input type="checkbox"/> Filters 9. <input type="checkbox"/> Pumps 10. <input type="checkbox"/> Flowmeter 11. <input checked="" type="checkbox"/> Pressure/Vacuum Gauges 12. <input checked="" type="checkbox"/> Skimmers & Gutters 13. <input type="checkbox"/> Pipes & Fittings 14. <input type="checkbox"/> Chemical Feeders 15. <input type="checkbox"/> Water Supply/Backflow Prevention	<b>Safety Equipment</b> 23. <input checked="" type="checkbox"/> Gates/Enclosure 24. <input type="checkbox"/> Drain Covers 25. <input type="checkbox"/> Anti-Entrapment Shutoff 26. <input type="checkbox"/> Rescue Pole 27. <input type="checkbox"/> Life Ring 28. <input checked="" type="checkbox"/> Safety Signs 29. <input type="checkbox"/> First Aid Kit 30. <input type="checkbox"/> Chlorine Gas Safety	<b>Miscellaneous</b> 38. <input type="checkbox"/> Chemical Test Kits 39. <input checked="" type="checkbox"/> Chemical Testing Frequency 40. <input checked="" type="checkbox"/> Record Keeping 41. <input type="checkbox"/> Lifeguards 42. <input type="checkbox"/> Communicable Disease Control 43. <input type="checkbox"/> Site Supervision & Control 44. <input type="checkbox"/> General Sanitation 45. <input type="checkbox"/> Other:

Comments:

**\*\* Pool is closed on the above date & time for the following critical violations:**

**\*\* CRITICAL VIOLATIONS \*\***

**(16) MAINTAIN POOL pH BETWEEN 7.2 - 7.8 AT ALL TIMES POOL IS OPEN. ✓ pH MEASURED 7.9.**

**(17) MAINTAIN FREE AVAILABLE CHLORINE BETWEEN 2.0 PPM TO 10 PPM. AT ALL TIMES POOL IS OPEN. ✓ POOL MEASURED NON-DETECT FOR F.A.C..**

**(23) THE SPRINGS ON THE POOL GATE MUST BE TIGHTENED OR RE-ADJUSTED SO THAT GATE CLOSES & LATCHES 100% OF THE TIME.**

**OTHER VIOLATIONS**

**(11) REPAIR/REPLACE BROKEN VACUUM GAUGE ON PUMP BASKET HOUSING.**

Received By: [Signature] REHS: ANDREW PERNO →

~~Pool~~  
**FOOD FACILITY INSPECTION REPORT**

**Continuation Sheet**

**GLENN COUNTY ENVIRONMENTAL HEALTH DEPARTMENT**

247 North Villa Avenue, Willows, CA 95988  
Phone (530) 934-6102 FAX (530) 934-6103

Page 2 of 2

Name of Facility/DBA: <u>BEST WESTERN WILLOWS INN</u>	Inspection Date: <u>5/13/19</u>
Address: <u>PAGE 2</u>	
Owner/Permittee: <u>PAGE 2</u>	
Applicable Law CALIFORNIA RETAIL FOOD CODE ("CalCode), Beginning with section 113700, California Health and Safety Code	

Comments:

OTHER VIOLATIONS

(12) LOWER THE POOL WATER LEVEL SO THAT THE SKIMMER SYSTEM CAN FUNCTION EFFECTIVELY.

(19) CLEAN & REMOVE DEBRIS/LEAVES/DIRT FROM THE POOL.

(28) ALL WRITING ON THE SAFETY SIGN MUST BE RE-WRITTEN SO THAT IT IS CLEARLY VISABLE.

(39)+(40) RECORD & TEST THE POOL pH & FREE AVAILABLE CHLORINE ON A DAILY BASIS & THE CYANURIC ACID STABILIZER ONCE A MONTH.

THE LOG LACKED READINGS ON WEEKEND DAYS AND DIDN'T HAVE A STABILIZER READING AT ALL.

NOTE: POOL TO REMAIN CLOSED UNTIL ALL VIOLATIONS CORRECTED AND RE-INSPECTED BY GLENN CO. ENVIRONMENTAL HEALTH.

Received By: <u>X Chellid</u>	REHS: <u>ANDREW PERGO</u>
-------------------------------	---------------------------