

# SWIMMING POOL OFFICIAL INSPECTION REPORT

## GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988  
Phone: (530) 934-6102 • Fax: (530) 934-6103

Page 1 of 2

Name of Facility/DBA: <b>HOLIDAY INN EXPRESS</b>			Inspection Date: <b>6/10/21</b>		
Address: <b>545 HAMBOLDT AVE, WILLOWS, CA</b>			Reinspection Date (on or after): <b>* SPA IS CLOSED</b> <small>(Reinspections are subject to fees)</small>		
Owner/Permittee: <b>KUMAR HOTELS INC.</b>		Phone Number:		Inspection Time: <b>4:00</b>	Permit Expiration Date:
Pool Type: <input type="checkbox"/> Swimming Pool <input checked="" type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other			Service: <input checked="" type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other		
pH: <b>7.0</b>	Free Chlorine: <b>10.19 PPM</b>	Combined Chlorine: <b>-</b>	Cyanuric Acid: <b>10 PPM</b>	Flow Rate: <b>40 GPM</b>	Temperature: <b>-</b>
Other: <b>-</b>					
Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20					

<b>Pool Construction</b> 1. <input type="checkbox"/> Pool Shell 2. <input type="checkbox"/> Bottom & Sides 3. <input checked="" type="checkbox"/> Decks & Coping 4. <input type="checkbox"/> Diving Boards 5. <input type="checkbox"/> Depth Markers 6. <input type="checkbox"/> Ladders/Steps/Railings 7. <input type="checkbox"/> Underwater Lighting & Electrical	<b>Water Quality</b> 16. <input checked="" type="checkbox"/> pH 17. <input checked="" type="checkbox"/> Chlorine/Bromine 18. <input type="checkbox"/> Cyanuric Acid 19. <input type="checkbox"/> Debris in Pool 20. <input type="checkbox"/> Water Clarity 21. <input type="checkbox"/> Temperature 22. <input type="checkbox"/> Flow Rate/Turnover	<b>General Facilities</b> 31. <input type="checkbox"/> Exterior Lighting 32. <input type="checkbox"/> Indoor Ventilation 33. <input type="checkbox"/> Restrooms & Toilets 34. <input type="checkbox"/> Handwash Sinks 35. <input type="checkbox"/> Dressing Rooms 36. <input type="checkbox"/> Showers 37. <input type="checkbox"/> Drinking Fountains
<b>Recirculation Equipment</b> 8. <input type="checkbox"/> Filters 9. <input type="checkbox"/> Pumps 10. <input type="checkbox"/> Flowmeter 11. <input checked="" type="checkbox"/> Pressure/Vacuum Gauges 12. <input type="checkbox"/> Skimmers & Gutters 13. <input type="checkbox"/> Pipes & Fittings 14. <input type="checkbox"/> Chemical Feeders 15. <input type="checkbox"/> Water Supply/Backflow Prevention	<b>Safety Equipment</b> 23. <input type="checkbox"/> Gates/Enclosure 24. <input type="checkbox"/> Drain Covers 25. <input type="checkbox"/> Anti-Entrapment Shutoff 26. <input type="checkbox"/> Rescue Pole 27. <input type="checkbox"/> Life Ring 28. <input type="checkbox"/> Safety Signs 29. <input type="checkbox"/> First Aid Kit 30. <input type="checkbox"/> Chlorine Gas Safety	<b>Miscellaneous</b> 38. <input type="checkbox"/> Chemical Test Kits 39. <input type="checkbox"/> Chemical Testing Frequency 40. <input type="checkbox"/> Record Keeping 41. <input type="checkbox"/> Lifeguards 42. <input type="checkbox"/> Communicable Disease Control 43. <input type="checkbox"/> Site Supervision & Control 44. <input type="checkbox"/> General Sanitation 45. <input checked="" type="checkbox"/> Other:

Comments:

**\*\* POOL & SPA ARE CLOSED ON THE ABOVE DATE & TIME DUE TO VIOLATIONS OF THE CALIFORNIA HEALTH & SAFETY CODE. THE SPA HAS CLOSURE VIOLATIONS AND ACCESS TO POOL/SPA CANNOT BE CONTROLLED INDEPENDENT VIOLATIONS:**

**③ OWNER/OPERATOR INSTALLED NEW POOL DECKING THAT DOES NOT MEET THE CALIFORNIA BLDG. CODE, TITLE 24, SECTION 3114B FOR POOL DECKS. OWNER MUST REMOVE INSTALLED DECK. ANY CHANGES, REMODELS TO A PUBLIC POOL MUST BE PLAN CHECKED AND APPROVED BY G.C.E.H.**

**⑪ ALL PRESSURE & VACUUM GAUGES MUST BE REPLACED WITH ONES THAT CAN BE REAP.**

**⑫ MAINTAIN POOL PH BETWEEN 7.2-7.8 AT ALL TIMES.**

**⑬ MAINTAIN SPA FREE CHLORINE LEVEL 7.0 PPM AT ALL TIMES. SPA MEASURED 7.0**

**⑭ SPA MEASURED ONLY 0.19 PPM**

Received By: REHS: **ANDREW PERRY**

Pool

~~POOL~~ FACILITY INSPECTION REPORT

Continuation Sheet

GLENN COUNTY ENVIRONMENTAL HEALTH DEPARTMENT

247 North Villa Avenue, Willows, CA 95988  
Phone (530) 934-6102 FAX (530) 934-6103

Page 2 of 2

Name of Facility/ DBA: <u>HOLIDAY INN EXPRESS SPA</u>	Inspection Date: <u>6/10/21</u>
Address:	<u>PAGE 2</u>
Owner/Permitee:	
Applicable Law CALIFORNIA RETAIL FOOD CODE ("CalCode), Beginning with section 113700, California Health and Safety Code	

Comments: VIOLATIONS (CONT.)

45 REPLACE BROKEN ~~EMERGENCY~~ EMERGENCY SHUT OFF SWITCH AT THE SPA.

Received By: <u>[Signature]</u>	REHS: <u>Andrew Perry</u>
---------------------------------	---------------------------