

SWIMMING POOL OFFICIAL INSPECTION REPORT

GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988

Phone: (530) 934-6102 • Fax: (530) 934-6103

Page 1 of 2

Name of Facility/DBA: BAYMONT INN & SUITES				Inspection Date: 6/4/19			
Address: 199 N. HUMBOLDT AVE, WILLOWS, CA				Reinspection Date (on or after): NEXT INSPECTION <small>(Reinspections are subject to fees)</small>			
Owner/Permittee: ROGER KUMAR			Phone Number:		Inspection Time: 4:00		Permit Expiration Date:
Pool Type: <input checked="" type="checkbox"/> Swimming Pool <input type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other			Service: <input checked="" type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other				
pH: 7.0	Free Chlorine: ~1.3 PPM	Combined Chlorine: NOT TESTED	Cyanuric Acid: ~26 PPM	Flow Rate: UNABLE TO TEST	Temperature: -	Other: -	
Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20							

Pool Construction 1. <input type="checkbox"/> Pool Shell 2. <input checked="" type="checkbox"/> Bottom & Sides 3. <input checked="" type="checkbox"/> Decks & Coping 4. <input type="checkbox"/> Diving Boards 5. <input type="checkbox"/> Depth Markers 6. <input type="checkbox"/> Ladders/Steps/Railings 7. <input type="checkbox"/> Underwater Lighting & Electrical	Water Quality 16. <input checked="" type="checkbox"/> pH 17. <input type="checkbox"/> Chlorine/Bromine 18. <input type="checkbox"/> Cyanuric Acid 19. <input type="checkbox"/> Debris in Pool 20. <input type="checkbox"/> Water Clarity 21. <input type="checkbox"/> Temperature 22. <input type="checkbox"/> Flow Rate/Turnover	General Facilities 31. <input type="checkbox"/> Exterior Lighting 32. <input type="checkbox"/> Indoor Ventilation 33. <input type="checkbox"/> Restrooms & Toilets 34. <input type="checkbox"/> Handwash Sinks 35. <input type="checkbox"/> Dressing Rooms 36. <input type="checkbox"/> Showers 37. <input type="checkbox"/> Drinking Fountains
Recirculation Equipment 8. <input checked="" type="checkbox"/> Filters 9. <input type="checkbox"/> Pumps 10. <input checked="" type="checkbox"/> Flowmeter 11. <input checked="" type="checkbox"/> Pressure/Vacuum Gauges 12. <input type="checkbox"/> Skimmers & Gutters 13. <input type="checkbox"/> Pipes & Fittings 14. <input type="checkbox"/> Chemical Feeders 15. <input type="checkbox"/> Water Supply/Backflow Prevention	Safety Equipment 23. <input checked="" type="checkbox"/> Gates/Enclosure 24. <input type="checkbox"/> Drain Covers 25. <input type="checkbox"/> Anti-Entrapment Shutoff 26. <input type="checkbox"/> Rescue Pole 27. <input type="checkbox"/> Life Ring 28. <input checked="" type="checkbox"/> Safety Signs 29. <input type="checkbox"/> First Aid Kit 30. <input type="checkbox"/> Chlorine Gas Safety	Miscellaneous 38. <input type="checkbox"/> Chemical Test Kits 39. <input type="checkbox"/> Chemical Testing Frequency 40. <input type="checkbox"/> Record Keeping 41. <input type="checkbox"/> Lifeguards 42. <input type="checkbox"/> Communicable Disease Control 43. <input checked="" type="checkbox"/> Site Supervision & Control 44. <input type="checkbox"/> General Sanitation 45. <input type="checkbox"/> Other:

Comments: Violations:

② RE PLASTER SHELL OF THE POOL (REQUIRES PLAN CHECK AT G.C.E.H.). PLASTER IS PITTED & DAMAGED IN A FEW LOCATIONS

③ REPAIR MISSING GROUT AT TILE/BULLNOSE COPING JUNCTURE ALONG POOL EDGE.

⑧ REPAIR FILTER MANAFORD SO THAT SAND DOES NOT LEAK INTO THE POOL ~ OBSERVED SAND ACCUMULATION IN THE POOL.

⑩ REPAIR/REPLACE FAULTY FLOW METER.

⑪ INSTALL A VACUUM METER ON THE SUCTION SIDE OF THE RECIRCULATION SYSTEM.

⑬ MAINTAIN POOL pH BETWEEN 7.2-7.8 AT ALL TIMES. ~ POOL pH MEASURED LOW AT 7.0, WHICH WILL IRRITATE

Received By:  REHS: 

FOOD FACILITY INSPECTION REPORT
Continuation Sheet
GLENN COUNTY ENVIRONMENTAL HEALTH DEPARTMENT
247 North Villa Avenue, Willows, CA 95988
Phone (530) 934-6102 FAX (530) 934-6103

Name of Facility/ DBA: <u>Baymont Inn & Suites</u>	Inspection Date: <u>6/4/19</u>
Address: <u>PAGE 2</u>	
Owner/Permitee: <u>PAGE 2</u>	
Applicable Law <i>CALIFORNIA RETAIL FOOD CODE ("CalCode), Beginning with section 113700, California Health and Safety Code</i>	

Comments: Violations (CONT.):

(16) SWIMMERS EYES.

(23) ALL DOORS MUST REMAIN CLOSED AND NOT PROPPED OPEN. DOORS & GATES MUST BE SELF CLOSING & LATCHING.

(20) PROVIDE DIARRHEA SIGN WITH THE VERBIAGE:
"PERSONS WITH ACTIVE DIARRHEA OR WHO HAVE HAD
DIARRHEA WITHIN 14 DAYS SHALL NOT ENTER WATER."

(43) DO NOT STORE MURIATIC ACID NEXT TO SODIUM
HYPOCHLORITE BLEACH. THIS IS A CHEMICAL STORAGE
HAZARD AND CAN CAUSE INJURY OR DEATH."
OBSERVED CHEMICALS STORED NEXT TO ONE ANOTHER
IN EQUIPMENT ROOM.

Received By: <u>[Signature]</u>	REHS: <u>Andrew Petyo</u>
---------------------------------	---------------------------