

SWIMMING POOL OFFICIAL INSPECTION REPORT

GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988
Phone: (530) 934-6102 • Fax: (530) 934-6103

Page 1 of 1

Name of Facility/DBA: Parleway RV Resort Pool				Inspection Date: 7/8/20	
Address: 6330 County Road 200, Orland, CA 95963				Reinspection Date (on or after): Next Inspection <small>(Reinspections are subject to fees)</small>	
Owner/Permittee: John & Marion Smutney		Phone Number: 865-9188		Inspection Time: 3:10pm	Permit Expiration Date: -
Pool Type: <input checked="" type="checkbox"/> Swimming Pool <input type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other			Service: <input checked="" type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other		
pH: 7.7	Free Chlorine: 3.6 ppm	Combined Chlorine: 0 ppm	Cyanuric Acid: 84 ppm	Flow Rate: 45 gpm	Temperature: 103 ppm
Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20					

<p>Pool Construction</p> <p>1. <input type="checkbox"/> Pool Shell</p> <p>2. <input checked="" type="checkbox"/> Bottom & Sides</p> <p>3. <input type="checkbox"/> Decks & Coping</p> <p>4. <input type="checkbox"/> Diving Boards</p> <p>5. <input type="checkbox"/> Depth Markers</p> <p>6. <input type="checkbox"/> Ladders/Steps/Railings</p> <p>7. <input type="checkbox"/> Underwater Lighting & Electrical</p> <p>Recirculation Equipment</p> <p>8. <input type="checkbox"/> Filters</p> <p>9. <input type="checkbox"/> Pumps</p> <p>10. <input type="checkbox"/> Flowmeter</p> <p>11. <input type="checkbox"/> Pressure/Vacuum Gauges</p> <p>12. <input type="checkbox"/> Skimmers & Gutters</p> <p>13. <input type="checkbox"/> Pipes & Fittings</p> <p>14. <input type="checkbox"/> Chemical Feeders</p> <p>15. <input type="checkbox"/> Water Supply/Backflow Prevention</p>	<p>Water Quality</p> <p>16. <input type="checkbox"/> pH</p> <p>17. <input type="checkbox"/> Chlorine/Bromine</p> <p>18. <input type="checkbox"/> Cyanuric Acid</p> <p>19. <input type="checkbox"/> Debris in Pool</p> <p>20. <input type="checkbox"/> Water Clarity</p> <p>21. <input type="checkbox"/> Temperature</p> <p>22. <input checked="" type="checkbox"/> Flow Rate/Turnover</p> <p>Safety Equipment</p> <p>23. <input type="checkbox"/> Gates/Enclosure</p> <p>24. <input type="checkbox"/> Drain Covers</p> <p>25. <input type="checkbox"/> Anti-Entrapment Shutoff</p> <p>26. <input type="checkbox"/> Rescue Pole</p> <p>27. <input type="checkbox"/> Life Ring</p> <p>28. <input checked="" type="checkbox"/> Safety Signs</p> <p>29. <input type="checkbox"/> First Aid Kit</p> <p>30. <input type="checkbox"/> Chlorine Gas Safety</p>	<p>General Facilities</p> <p>31. <input type="checkbox"/> Exterior Lighting</p> <p>32. <input type="checkbox"/> Indoor Ventilation</p> <p>33. <input type="checkbox"/> Restrooms & Toilets</p> <p>34. <input type="checkbox"/> Handwash Sinks</p> <p>35. <input type="checkbox"/> Dressing Rooms</p> <p>36. <input type="checkbox"/> Showers</p> <p>37. <input type="checkbox"/> Drinking Fountains</p> <p>Miscellaneous</p> <p>38. <input type="checkbox"/> Chemical Test Kits</p> <p>39. <input type="checkbox"/> Chemical Testing Frequency</p> <p>40. <input type="checkbox"/> Record Keeping</p> <p>41. <input type="checkbox"/> Lifeguards</p> <p>42. <input type="checkbox"/> Communicable Disease Control</p> <p>43. <input type="checkbox"/> Site Supervision & Control</p> <p>44. <input type="checkbox"/> General Sanitation</p> <p>45. <input type="checkbox"/> Other:</p>
---	--	--

2) Repair the two tiles pulling from deep end side of pool. Tiles are secure to wall, but can cut patrons.

23) Increase flow rate to 56 gpm. Measured 45 gpm.

28) Repaint faded "No Diving" signage on deck.

Received By:	REHS: John H. Wells
--------------	----------------------------