

SWIMMING POOL OFFICIAL INSPECTION REPORT

GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988
Phone: (530) 934-6102 • Fax: (530) 934-6103

Name of Facility/DBA: <u>Tierradel Sal Apartments Pool</u>		Inspection Date: <u>8/1/19</u>	
Address: <u>73 E. Walker St, Orland, CA 95963</u>		Reinspection Date (on or after): <u>By Department</u> <small>(Reinspections are subject to fees)</small>	
Owner/Permittee: <u>Robert Howard</u>	Phone Number: <u>204-8126</u>	Inspection Time: <u>11:20 am</u>	Permit Expiration Date:
Pool Type: <input checked="" type="checkbox"/> Swimming Pool <input type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other	Service: <input checked="" type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other		
pH: <u>7.7</u>	Free Chlorine: <u>0.2 ppm</u>	Combined Chlorine: <u>0 ppm</u>	Cyanuric Acid: <u>140 ppm</u>
Flow Rate: <u>could not determine</u>		Temperature: <u>Total alk - Ca Hardness +</u>	Other:
Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20			

Pool Construction 1. <input type="checkbox"/> Pool Shell 2. <input type="checkbox"/> Bottom & Sides 3. <input type="checkbox"/> Decks & Coping 4. <input type="checkbox"/> Diving Boards 5. <input type="checkbox"/> Depth Markers 6. <input type="checkbox"/> Ladders/Steps/Railings 7. <input type="checkbox"/> Underwater Lighting & Electrical	Water Quality 16. <input type="checkbox"/> pH 17. <input checked="" type="checkbox"/> Chlorine/Bromine 18. <input checked="" type="checkbox"/> Cyanuric Acid 19. <input type="checkbox"/> Debris in Pool 20. <input checked="" type="checkbox"/> Water Clarity 21. <input type="checkbox"/> Temperature 22. <input type="checkbox"/> Flow Rate/Turnover	General Facilities 31. <input type="checkbox"/> Exterior Lighting 32. <input type="checkbox"/> Indoor Ventilation 33. <input type="checkbox"/> Restrooms & Toilets 34. <input type="checkbox"/> Handwash Sinks 35. <input type="checkbox"/> Dressing Rooms 36. <input type="checkbox"/> Showers 37. <input type="checkbox"/> Drinking Fountains
Recirculation Equipment 8. <input type="checkbox"/> Filters 9. <input type="checkbox"/> Pumps 10. <input type="checkbox"/> Flowmeter 11. <input type="checkbox"/> Pressure/Vacuum Gauges 12. <input type="checkbox"/> Skimmers & Gutters 13. <input type="checkbox"/> Pipes & Fittings 14. <input type="checkbox"/> Chemical Feeders 15. <input type="checkbox"/> Water Supply/Backflow Prevention	Safety Equipment 23. <input checked="" type="checkbox"/> Gates/Enclosure 24. <input type="checkbox"/> Drain Covers 25. <input type="checkbox"/> Anti-Entrapment Shutoff 26. <input type="checkbox"/> Rescue Pole 27. <input checked="" type="checkbox"/> Life Ring 28. <input checked="" type="checkbox"/> Safety Signs 29. <input type="checkbox"/> First Aid Kit 30. <input type="checkbox"/> Chlorine Gas Safety	Miscellaneous 38. <input type="checkbox"/> Chemical Test Kits 39. <input type="checkbox"/> Chemical Testing Frequency 40. <input type="checkbox"/> Record Keeping 41. <input type="checkbox"/> Lifeguards 42. <input type="checkbox"/> Communicable Disease Control 43. <input type="checkbox"/> Site Supervision & Control 44. <input checked="" type="checkbox"/> General Sanitation 45. <input type="checkbox"/> Other:

Comments:
 * Pool is closed! Do not reopen without approval from our department.

Critical Violations (Closure Violations)

17) Maintain free available chlorine between ~~1.0-10.0~~ 2.0-10.0 ppm. Measured 0.2 ppm.

18) Maintain cyanuric acid below 100 ppm. Measured 140 ppm.

20) Eliminate cloudiness from water so that main drain is easily visible from shallow end of pool. Pool water is white & cloudy.

23) Repair main gate so it reliably self-closes and self-latches. Gate does not self-close reliably.

Received By: [Signature] REHS: John H. Wells

FOOD FACILITY INSPECTION REPORT

Continuation Sheet

GLENN COUNTY ENVIRONMENTAL HEALTH DEPARTMENT

247 North Villa Avenue, Willows, CA 95988
Phone (530) 934-6102 FAX (530) 934-6103

Page 2 of 2

Name of Facility/ DBA: <u>Tierra del Sol Apartments Pool</u>	Inspection Date: <u>8/1/19</u>
Address: <u>73 E. Walker St, Orland, CA 95963</u>	
Owner/Permittee: <u>Robert Howard</u>	
Applicable Law CALIFORNIA RETAIL FOOD CODE ("CalCode), Beginning with section 113700, California Health and Safety Code	

Comments:

Other violations

10) Repair/replace inoperable flow meter.

27) Provide/attach rope to life ring that is at least as long as the maximum width of pool. Life ring has no rope.

28) Provide all necessary safety signs. All required signs are missing or faded/unreadable. Required signs include:

- Pool Capacity (20 persons)
- "Keep Closed" (on gate)
- "No Diving"
- Bannha sign
- "No Lifeguard on Duty"
- Emergency Phone Number
- Address of pool

4A) Clean bugs from skimmer.

Recommendations

Chemical	Measured	Desired Range	Ideal
Total Alkalinity	115 ppm	80-120 ppm	100 ppm
Calcium Hardness	426 ppm	200-350 ppm	250 ppm

Note: calcium hardness can cause cloudy water if too high or low. This may or may not be causing pool cloudiness.

Received By: <u>[Signature]</u>	REHS: <u>John H. Wells</u>
---------------------------------	----------------------------