

# SWIMMING POOL OFFICIAL INSPECTION REPORT

## GLENN COUNTY ENVIRONMENTAL HEALTH

225 N. Tehama Street, Willows, CA 95988  
Phone (530) 934-6102 FAX (530) 934-6103

Page 1 of \_\_\_\_\_

Name of Facility / DBA: <b>Holiday Inn Express</b>		Inspection Date: <b>8/30/21</b>	
Address: <b>545 N. Humboldt Ave, Willows, CA</b>		Reinspection Date (one or after): <b>*SPA IS CLOSED</b> <small>(Reinspections are subject to fees)</small>	
Owner/Permittee: <b>KUMAR HOTELS INC.</b>	Phone Number:	Inspection Time: <b>4:00</b>	Permit Expiration Date:
Pool Type: <input type="checkbox"/> Swimming Pool <input checked="" type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other	Service: <input checked="" type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other		
pH: <b>7.2</b>	Free Chlorine: <b>~1.4 PPM</b>	Combined Chlorine: <b>-</b>	Cyanuric Acid: <b>~10 PPM</b>
	Flow Rate: <b>50 GPM</b>	Temperature: <b>-</b>	Other: <b>-</b>

*Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20*

<b>Pool Construction</b> 1. <input type="checkbox"/> Pool Shell 2. <input type="checkbox"/> Bottom & Sides 3. <input checked="" type="checkbox"/> Decks & Coping 4. <input type="checkbox"/> Diving Boards 5. <input type="checkbox"/> Depth Markers 6. <input type="checkbox"/> Ladders/Steps/Railings 7. <input type="checkbox"/> Underwater Lighting & Electrical	<b>Water Quality</b> 16. <input type="checkbox"/> pH 17. <input checked="" type="checkbox"/> Chlorine/Bromine 18. <input type="checkbox"/> Cyanuric Acid 19. <input type="checkbox"/> Debris in Pool 20. <input type="checkbox"/> Water Clarity 21. <input type="checkbox"/> Temperature 22. <input type="checkbox"/> Flow Rate/Turnover	<b>General Facilities</b> 31. <input type="checkbox"/> Exterior Lighting 32. <input type="checkbox"/> Indoor Ventilation 33. <input type="checkbox"/> Restrooms & Toilets 34. <input type="checkbox"/> Handwash Sinks 35. <input type="checkbox"/> Dressing Room 36. <input type="checkbox"/> Showers 37. <input type="checkbox"/> Drinking Fountains
<b>Recirculation Equipment</b> 8. <input type="checkbox"/> Filters 9. <input type="checkbox"/> Pumps 10. <input type="checkbox"/> Flowmeter 11. <input type="checkbox"/> Pressure/Vacuum Gauges 12. <input type="checkbox"/> Skimmers & Gutters 13. <input checked="" type="checkbox"/> Pipes & Fittings 14. <input checked="" type="checkbox"/> Chemical Feeders 15. <input type="checkbox"/> Water Supply/Backflow Prevention	<b>Safety Equipment</b> 23. <input type="checkbox"/> Gates/Enclosure 24. <input type="checkbox"/> Drain Covers 25. <input type="checkbox"/> Anti-Entrapment Shutoff 26. <input type="checkbox"/> Rescue Pole 27. <input type="checkbox"/> Life Ring 28. <input checked="" type="checkbox"/> Safety Signs 29. <input type="checkbox"/> First Aid Kit 30. <input type="checkbox"/> Chlorine Gas Safety	<b>Miscellaneous</b> 38. <input type="checkbox"/> Chemical Test Kits 39. <input type="checkbox"/> Chemical Testing Frequency 40. <input checked="" type="checkbox"/> Record Keeping 41. <input type="checkbox"/> Lifeguards 42. <input type="checkbox"/> Communicable Disease Control 43. <input type="checkbox"/> Site Supervision & Control 44. <input type="checkbox"/> General Sanitation 45. <input type="checkbox"/> Other:

Comments:  
**\*\* SPA IS CLOSED ON THE ABOVE DATE & TIME DUE TO THE FOLLOWING CRITICAL VIOLATIONS:**  
**\*\* CRITICAL VIOLATIONS \*\***  
**(17) MAINTAIN SPA FREE AVAILABLE CHLORINE AT OR ABOVE 3.0 PPM AND BELOW 10 PPM. SPA MEASURED 1.4 PPM**  
**OTHER VIOLATIONS**  
**(3) THE DECK SHALL BE REPAIRED IN ACCORDANCE TO THE PLANS SUBMITTED TO GLENN CO. E.H. BY SEPT. 24<sup>TH</sup>.**  
**(13) ALL PLUMBING SHALL HAVE DIRECTION OF FLOW ARROWS PRINTED ON THEM.**  
**(14) REPAIR THE LEAKY/DRIPY TABLET CHLORINE FEEDER.**  
**(28) THE NORTH ENTRY GATE MUST HAVE A "KEEP GATE CLOSED" SIGN ON THE DOOR.**  
**(40) RECORD KEEPING APPEARS TO BE "DRY LOGGED" AS THE CHEMICALS BEING RECORDED DONT CHANGE IN CONCENTRATION FROM DAY TO DAY.**

Received By:	REHS: <b>ANDREW PERRY</b>
--------------	---------------------------