

SWIMMING POOL OFFICIAL INSPECTION REPORT

GLENN COUNTY ENVIRONMENTAL HEALTH

225 N. Tehama Street, Willows, CA 95988
Phone (530) 934-6102 FAX (530) 934-6103

Page 1 of _____

Name of Facility / DBA: HOLIDAY INN EXPRESS SPA			Inspection Date: 9/7/22		
Address: 545 N. HUMBOLDT AVE, WILLOWS			Reinspection Date (one or after): *CLOSED* <small>(Reinspections are subject to fees)</small>		
Owner/Permittee: KUMAR HOTELS INC.		Phone Number:	Inspection Time: 3:30	Permit Expiration Date:	
Pool Type: <input type="checkbox"/> Swimming Pool <input checked="" type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other			Service: <input checked="" type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other		
pH: > 8.2	Free Chlorine: > 10 PPM	Combined Chlorine: -	Cyanuric Acid: NOT TESTED	Flow Rate: UNABLE TO TEST	Temperature: 10.2°F
Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20					

Pool Construction 1. <input type="checkbox"/> Pool Shell 2. <input type="checkbox"/> Bottom & Sides 3. <input type="checkbox"/> Decks & Coping 4. <input type="checkbox"/> Diving Boards 5. <input type="checkbox"/> Depth Markers 6. <input type="checkbox"/> Ladders/Steps/Railings 7. <input type="checkbox"/> Underwater Lighting & Electrical Recirculation Equipment 8. <input type="checkbox"/> Filters 9. <input type="checkbox"/> Pumps 10. <input checked="" type="checkbox"/> Flowmeter 11. <input checked="" type="checkbox"/> Pressure/Vacuum Gauges 12. <input type="checkbox"/> Skimmers & Gutters 13. <input checked="" type="checkbox"/> Pipes & Fittings 14. <input type="checkbox"/> Chemical Feeders 15. <input type="checkbox"/> Water Supply/Backflow Prevention	Water Quality 16. <input checked="" type="checkbox"/> pH 17. <input checked="" type="checkbox"/> Chlorine/Bromine 18. <input type="checkbox"/> Cyanuric Acid 19. <input type="checkbox"/> Debris in Pool 20. <input type="checkbox"/> Water Clarity 21. <input type="checkbox"/> Temperature 22. <input type="checkbox"/> Flow Rate/Turnover Safety Equipment 23. <input type="checkbox"/> Gates/Enclosure 24. <input type="checkbox"/> Drain Covers 25. <input type="checkbox"/> Anti-Entrapment Shutoff 26. <input type="checkbox"/> Rescue Pole 27. <input type="checkbox"/> Life Ring 28. <input type="checkbox"/> Safety Signs 29. <input type="checkbox"/> First Aid Kit 30. <input type="checkbox"/> Chlorine Gas Safety	General Facilities 31. <input type="checkbox"/> Exterior Lighting 32. <input type="checkbox"/> Indoor Ventilation 33. <input type="checkbox"/> Restrooms & Toilets 34. <input type="checkbox"/> Handwash Sinks 35. <input type="checkbox"/> Dressing Room 36. <input type="checkbox"/> Showers 37. <input type="checkbox"/> Drinking Fountains Miscellaneous 38. <input type="checkbox"/> Chemical Test Kits 39. <input checked="" type="checkbox"/> Chemical Testing Frequency 40. <input checked="" type="checkbox"/> Record Keeping 41. <input type="checkbox"/> Lifeguards 42. <input type="checkbox"/> Communicable Disease Control 43. <input type="checkbox"/> Site Supervision & Control 44. <input type="checkbox"/> General Sanitation 45. <input type="checkbox"/> Other:
--	---	--

Comments:

**** SPA & CONSEQUENTLY THE POOL IS CLOSED ON THE ABOVE DATE AND TIME DUE TO SAFETY VIOLATIONS IN THE SPA. ****

Violations:

(6) MAINTAIN SPA pH BETWEEN 7.2 - 7.8 AT ALL TIMES. SPA MEASURED > 8.2.

(7) MAINTAIN FREE AVAILABLE CHLORINE GREATER THAN 3.0 PPM BUT LESS THAN 10 PPM AT ALL TIMES. SPA MEASURED > 10 PPM.

(10) REPAIR/REPLACE BROKEN FLOW METER

(11) REPAIR THE PRESSURE GAUGE ON SPA FILTER SO THAT IT EASILY VISABLE DURING INSPECTION.

(13) REPAIR THE LEAK ON THE COLLAR OF THE FILTER HOUSING.

(39) (40) TEST AND RECORD ONCE PER MONTH THE CYANURIC ACID STABILIZER.

Received By: <i>[Signature]</i>	REHS: <i>[Signature]</i>
---------------------------------	--------------------------