

SWIMMING POOL OFFICIAL INSPECTION REPORT

GLENN COUNTY ENVIRONMENTAL HEALTH

225 N. Tehama Street, Willows, CA 95988
Phone (530) 934-6102 FAX (530) 934-6103

Page 1 of 1

Name of Facility / DBA: <u>VILLA COURT TOWNHOMES</u>				Inspection Date: <u>9/8/21</u>			
Address: <u>127 VILLA COURT, WILLOWS, CA</u>				Reinspection Date (one or after): <u>NEXT INSPECTION</u> <small>(Reinspections are subject to fees)</small>			
Owner/Permittee: <u>VILLA COURT TOWNHOMES</u>			Phone Number:		Inspection Time: <u>4:00</u>		Permit Expiration Date: <u>5/31/22</u>
Pool Type: <input checked="" type="checkbox"/> Swimming Pool <input type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other				Service: <input checked="" type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other			
pH: <u>7.4</u>	Free Chlorine: <u>6.2 PPM</u>	Combined Chlorine: <u>—</u>	Cyanuric Acid: <u>30 PPM</u>	Flow Rate: <u>UNABLE TO TEST</u>	Temperature: <u>—</u>	Other: <u>—</u>	
Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20							

Pool Construction 1. <input type="checkbox"/> Pool Shell 2. <input type="checkbox"/> Bottom & Sides 3. <input type="checkbox"/> Decks & Coping 4. <input type="checkbox"/> Diving Boards 5. <input type="checkbox"/> Depth Markers 6. <input type="checkbox"/> Ladders/Steps/Railings 7. <input type="checkbox"/> Underwater Lighting & Electrical	Water Quality 16. <input type="checkbox"/> pH 17. <input type="checkbox"/> Chlorine/Bromine 18. <input type="checkbox"/> Cyanuric Acid 19. <input type="checkbox"/> Debris in Pool 20. <input type="checkbox"/> Water Clarity 21. <input type="checkbox"/> Temperature 22. <input type="checkbox"/> Flow Rate/Turnover	General Facilities 31. <input type="checkbox"/> Exterior Lighting 32. <input type="checkbox"/> Indoor Ventilation 33. <input type="checkbox"/> Restrooms & Toilets 34. <input type="checkbox"/> Handwash Sinks 35. <input type="checkbox"/> Dressing Room 36. <input type="checkbox"/> Showers 37. <input type="checkbox"/> Drinking Fountains
Recirculation Equipment 8. <input checked="" type="checkbox"/> Filters 9. <input checked="" type="checkbox"/> Pumps 10. <input checked="" type="checkbox"/> Flowmeter 11. <input checked="" type="checkbox"/> Pressure/Vacuum Gauges 12. <input type="checkbox"/> Skimmers & Gutters 13. <input checked="" type="checkbox"/> Pipes & Fittings 14. <input checked="" type="checkbox"/> Chemical Feeders 15. <input type="checkbox"/> Water Supply/Backflow Prevention	Safety Equipment 23. <input type="checkbox"/> Gates/Enclosure 24. <input type="checkbox"/> Drain Covers 25. <input type="checkbox"/> Anti-Entrapment Shutoff 26. <input type="checkbox"/> Rescue Pole 27. <input type="checkbox"/> Life Ring 28. <input type="checkbox"/> Safety Signs 29. <input type="checkbox"/> First Aid Kit 30. <input type="checkbox"/> Chlorine Gas Safety	Miscellaneous 38. <input type="checkbox"/> Chemical Test Kits 39. <input checked="" type="checkbox"/> Chemical Testing Frequency 40. <input checked="" type="checkbox"/> Record Keeping 41. <input type="checkbox"/> Lifeguards 42. <input type="checkbox"/> Communicable Disease Control 43. <input checked="" type="checkbox"/> Site Supervision & Control 44. <input type="checkbox"/> General Sanitation 45. <input type="checkbox"/> Other:

Comments:

8, 9, 10, 11, 14, 39, 40, 43

*UNABLE TO ACCESS POOL EQUIPMENT ROOM, CHEMICAL TESTING RECORDS, MAINTENANCE LOGS. THE EQUIPMENT ROOM IS LOCKED. PROVIDE G.C.E.H WITH ACCESS OR A KEY SO THAT A FULL INSPECTION MAY BE COMPLETED

*NO OTHER VIOLATIONS OBSERVED AT THE TIME OF INSPECTION.

Received By: VIA MAIL SLOT REHS: ANDREW PETYO