

# SWIMMING POOL OFFICIAL INSPECTION REPORT

## GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988

Phone: (530) 934-6102 • Fax: (530) 934-6103

Name of Facility/DBA: <b>BAYMONT INN &amp; SUITES</b>		Inspection Date: <b>9/9/19</b>	
Address: <b>199 N. HUMBOLDT AVE., WILLOWS CA</b>		Reinspection Date (on or after): <b>NEXT INSPECTION</b> <small>(Reinspections are subject to fees)</small>	
Owner/Permittee: <b>ROGER KUMAR</b>	Phone Number:	Inspection Time: <b>4:00</b>	Permit Expiration Date:
Pool Type: <input checked="" type="checkbox"/> Swimming Pool <input type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other	Service: <input checked="" type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other		
pH: <b>7.6</b>	Free Chlorine: <b>~ 3.7 PPM</b>	Combined Chlorine: <b>NOT TESTED</b>	Cyanuric Acid: <b>~ 9 PPM</b>
Flow Rate: <b>UNABLE TO TEST</b>	Temperature: <b>-</b>	Other: <b>-</b>	

*Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20*

<b>Pool Construction</b> 1. <input type="checkbox"/> Pool Shell 2. <input checked="" type="checkbox"/> Bottom & Sides 3. <input checked="" type="checkbox"/> Decks & Coping 4. <input type="checkbox"/> Diving Boards 5. <input type="checkbox"/> Depth Markers 6. <input type="checkbox"/> Ladders/Steps/Railings 7. <input type="checkbox"/> Underwater Lighting & Electrical	<b>Water Quality</b> 16. <input type="checkbox"/> pH 17. <input type="checkbox"/> Chlorine/Bromine 18. <input type="checkbox"/> Cyanuric Acid 19. <input type="checkbox"/> Debris in Pool 20. <input type="checkbox"/> Water Clarity 21. <input type="checkbox"/> Temperature 22. <input type="checkbox"/> Flow Rate/Turnover	<b>General Facilities</b> 31. <input type="checkbox"/> Exterior Lighting 32. <input type="checkbox"/> Indoor Ventilation 33. <input type="checkbox"/> Restrooms & Toilets 34. <input type="checkbox"/> Handwash Sinks 35. <input type="checkbox"/> Dressing Rooms 36. <input type="checkbox"/> Showers 37. <input type="checkbox"/> Drinking Fountains
<b>Recirculation Equipment</b> 8. <input type="checkbox"/> Filters 9. <input type="checkbox"/> Pumps 10. <input checked="" type="checkbox"/> Flowmeter 11. <input checked="" type="checkbox"/> Pressure/Vacuum Gauges 12. <input type="checkbox"/> Skimmers & Gutters 13. <input type="checkbox"/> Pipes & Fittings 14. <input type="checkbox"/> Chemical Feeders 15. <input type="checkbox"/> Water Supply/Backflow Prevention	<b>Safety Equipment</b> 23. <input type="checkbox"/> Gates/Enclosure 24. <input type="checkbox"/> Drain Covers 25. <input type="checkbox"/> Anti-Entrapment Shutoff 26. <input type="checkbox"/> Rescue Pole 27. <input type="checkbox"/> Life Ring 28. <input type="checkbox"/> Safety Signs 29. <input type="checkbox"/> First Aid Kit 30. <input type="checkbox"/> Chlorine Gas Safety	<b>Miscellaneous</b> 38. <input type="checkbox"/> Chemical Test Kits 39. <input type="checkbox"/> Chemical Testing Frequency 40. <input checked="" type="checkbox"/> Record Keeping 41. <input type="checkbox"/> Lifeguards 42. <input type="checkbox"/> Communicable Disease Control 43. <input type="checkbox"/> Site Supervision & Control 44. <input type="checkbox"/> General Sanitation 45. <input type="checkbox"/> Other:

Comments: VIOLATIONS:

② RE-PLASTER SHELL OF THE POOL (REQUIRES PLAN CHECK AT G.C.E.H). PLASTER IS PITTED & DAMAGED IN A FEW LOCATIONS.

③ REPAIR BROKEN/MISSING BANDING AROUND THE POOL WHERE THE DECK MEETS THE COPING.

⑩ REPLACE/REPAIR THE BROKEN FLOW METER ON THE POOL CIRCULATION EQUIPMENT. REPEAT VIOLATION!

⑪ INSTALL A VACUUM METER ON THE SUCTION SIDE OF THE RE-CIRCULATION SYSTEM.

④⑩ RECORD IN LOG ALL MAINTENANCE ACTIVITIES WHEN RECORDING PH & FREE AVAILABLE CHLORINE.

Received By:	REHS:
--------------	-------