

## **COUNTY OF GLENN**

Department of General Services- Facilities 453 E. County Road 49 ½ Willows, CA 95988 Phone: 530-934-6545

<u>Facilities2@countyofglenn.net</u> www.countyofglenn.net

## SCOTT H. DEMOSS

County Administrative Officer 525 W. Sycamore St. Suite B1 Willows, CA 95988 Phone: 530-934-6400 Fax: 530-934-6419

Fax: 530-934-6419 <a href="mailto:gcboard@countyofglenn.net">gcboard@countyofglenn.net</a>

## **REQUEST FOR INFORMATION (RFI)**

Solicitation Description: Orland Memorial Park Accessibility and Beautification Project

**Solicitation Opening Date, Time:** Friday, August 18, 2023 at 11:00 a.m.

Location: Glenn County Clerk of the Board

525 W. Sycamore St. Willows, CA 95988

RFI Number: 002

RFI Date: Thursday, August 10, 2023

Contact: Joe Bettencourt, Supervising Staff Services Analyst- General Services

Ricardo Valdez, Facilities Operation Manager- General Services

Facilities2@countyofglenn.net, (530) 934-6545

Return one properly executed copy of this RFI with bid response or prior to the Bid Opening Date/Time listed above.

- **1. Question:** Bid Item No. 42, 1-1/2" size SCH 40 PVC mainline does not match with the size on dwg. no. IP-1. Mainline on IP-1 calls for a 2". Please clarify as to what mainline size is to be used, 1-1/2" or 2"?
- 1. Response: Mainline shall be 1-1/2" size per bid Item.
- 2. Question: Please confirm that the size for Bid Item No. 34 is correct, 3-inch SCH 40 PVC irrigation sleeve?
- 2. Response: Irrigation sleeve shall be 3-inch per bid item.
- 3. Question: Please confirm that the size for Bid Item No. 35 is correct, 1-1/2-inch SCH 40 PVC irrigation sleeve??
- **3. Response:** Irrigation sleeve shall be 1-1/2-inch per bid item.

This RFI has been emailed to interested vendors as well as posted here: <a href="http://www.countyofglenn.net/govt/bids">http://www.countyofglenn.net/govt/bids</a> Failure to acknowledge receipt of this RFI may result in rejection of the response.