

# SWIMMING POOL OFFICIAL INSPECTION REPORT

## GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988  
Phone: (530) 934-6102 • Fax: (530) 934-6103

Page 1 of 2

Name of Facility/DBA: <u>Willows Springs Senior Apts</u>		Inspection Date: <u>5/30/16</u>	
Address: <u>1340 W. Sycamore St., Willows CA</u>		Reinspection Date (on or after): <b>**POOL IS CLOSED**</b> <small>(Reinspections are subject to fees)</small>	
Owner/Permittee: <u>Willows Pacific Assoc., CALP</u>	Phone Number: <u>934-3411</u>	Inspection Time: <u>3:30</u>	Permit Expiration Date: <u>-</u>
Pool Type: <input checked="" type="checkbox"/> Swimming Pool <input type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other		Service: <input checked="" type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other	
pH: <u>7.6</u>	Free Chlorine: <u>ND</u>	Combined Chlorine: <u>NOT TESTED</u>	Cyanuric Acid: <u>APPROX 40PPM</u>
Flow Rate: <u>UNABLE TO TEST</u>		Temperature: <u>N/A</u>	Other: <u>-</u>

*Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20*

### Pool Construction

1.  Pool Shell
2.  Bottom & Sides
3.  Decks & Coping
4.  Diving Boards
5.  Depth Markers
6.  Ladders/Steps/Railings
7.  Underwater Lighting & Electrical

### Water Quality

16.  pH
17.  Chlorine/Bromine
18.  Cyanuric Acid
19.  Debris in Pool
20.  Water Clarity
21.  Temperature
22.  Flow Rate/Turnover

### General Facilities

31.  Exterior Lighting
32.  Indoor Ventilation
33.  Restrooms & Toilets
34.  Handwash Sinks
35.  Dressing Rooms
36.  Showers
37.  Drinking Fountains

### Recirculation Equipment

8.  Filters
9.  Pumps
10.  Flowmeter
11.  Pressure/Vacuum Gauges
12.  Skimmers & Gutters
13.  Pipes & Fittings
14.  Chemical Feeders
15.  Water Supply/Backflow Prevention

### Safety Equipment

23.  Gates/Enclosure
24.  Drain Covers
25.  Anti-Entrapment Shutoff
26.  Rescue Pole
27.  Life Ring
28.  Safety Signs
29.  First Aid Kit
30.  Chlorine Gas Safety

### Miscellaneous

38.  Chemical Test Kits
39.  Chemical Testing Frequency
40.  Record Keeping
41.  Lifeguards
42.  Communicable Disease Control
43.  Site Supervision & Control
44.  General Sanitation
45.  Other:

### Comments:

**\*\* Pool is closed on the above date & time for the following health violations.**

**\*\* CRITICAL VIOLATIONS \*\***

**(17) MAINTAIN PROPER CHLORINE CONCENTRATIONS IN THE POOL AT ALL TIMES. POOL WATER MEASURED NON-DETECT FOR FREE CHLORINE.**

OTHER VIOLATIONS

**(2) ~~REPAIR~~ OBSERVED MUSTARD ALGAE GROWTH ALONG SIDES OF THE POOL. MAINTAIN DISINFECTANT LEVEL AND BRUSH THE SIDES OF THE POOL.**

**(3) REPAIR POOL COPING SO THAT IT IS FLUSH WITH THE DECK. COPING HAS SEPERATED FROM THE DECK.**

**(8)(9)(10)(11) UNABLE TO ACCESS POOL EQUIPMENT ROOM FOR INSPECTION.**

Received By: U.S. MAIL

REHS: Andrew Petyo

~~Pool~~  
**FOOD FACILITY INSPECTION REPORT**  
**Continuation Sheet**  
**GLENN COUNTY ENVIRONMENTAL HEALTH DEPARTMENT**  
257 North Villa Avenue, Willows, CA 95988  
Phone (530) 934-6102 FAX (530) 934-6103

Page 2 of 2

Name of Facility/ DBA: <u>Willows Springs Senior Apts</u>	Inspection Date: <u>5/30/16</u>
Address: <u>PAGE 2</u>	
Owner/Permitee: <u>PAGE 2</u>	
Applicable Law CALIFORNIA RETAIL FOOD CODE ("CalCode), Beginning with section 113700, California Health and Safety Code	

Comments:

OTHER VIOLATIONS (CONT.):

⑫ MAINTAIN SKIMMERS SO THAT THEY CAN CLEAN THE SURFACE OF THE POOL. THE NORTH SKIMMER WAS OBSERVED TO BE FILLED / PLUGGED WITH DEBRIS.

⑩ - UNABLE TO INSPECT DAILY CHEMICAL / MAINTENANCE RECORDS AS MGR. WAS NOT PRESENT

NOTE: ONCE VIOLATIONS HAVE BEEN CORRECTED CONTACT G.C.E.H FOR RE-INSPECTION.  
RE-INSPECTIONS ARE SUBJECT TO FEES.

Received By:

U.S. MAIL

REHS:

Andrew Petyo