

SWIMMING POOL OFFICIAL INSPECTION REPORT
GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988
 Phone: (530) 934-6102 • Fax: (530) 934-6103

Name of Facility/DBA: BEST WESTERN WILLOWS INN			Inspection Date: 6/11/15			
Address: 475 N. HUMBOLDT AVE, WILLOWS, CA			Reinspection Date (on or after): * POOL IS CLOSED <small>(Reinspections are subject to fees)</small>			
Owner/Permittee: SURESH PATEL		Phone Number: 939-4444	Inspection Time: 3:00	Permit Expiration Date:		
Pool Type: <input checked="" type="checkbox"/> Swimming Pool <input type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other		Service: <input checked="" type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other				
pH: > 8.5	Free Chlorine: ND	Combined Chlorine: ND	Cyanuric Acid: DID NOT TEST	Flow Rate: 45 GPM	Temperature: N/A	Other: -
Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20						

Pool Construction 1. <input type="checkbox"/> Pool Shell 2. <input type="checkbox"/> Bottom & Sides 3. <input type="checkbox"/> Decks & Coping 4. <input type="checkbox"/> Diving Boards 5. <input type="checkbox"/> Depth Markers 6. <input type="checkbox"/> Ladders/Steps/Railings 7. <input type="checkbox"/> Underwater Lighting & Electrical Recirculation Equipment 8. <input type="checkbox"/> Filters 9. <input type="checkbox"/> Pumps 10. <input type="checkbox"/> Flowmeter 11. <input type="checkbox"/> Pressure/Vacuum Gauges 12. <input type="checkbox"/> Skimmers & Gutters 13. <input type="checkbox"/> Pipes & Fittings 14. <input type="checkbox"/> Chemical Feeders 15. <input type="checkbox"/> Water Supply/Backflow Prevention	Water Quality 16. <input checked="" type="checkbox"/> pH 17. <input checked="" type="checkbox"/> Chlorine 18. <input type="checkbox"/> Cyanuric Acid 19. <input type="checkbox"/> Other Chemicals 20. <input type="checkbox"/> Water Clarity 21. <input type="checkbox"/> Temperature 22. <input type="checkbox"/> Flow Rate/Turnover Safety Equipment 23. <input type="checkbox"/> Gates/Enclosure 24. <input type="checkbox"/> Drain Covers 25. <input type="checkbox"/> Anti-Entrapment Shutoff 26. <input checked="" type="checkbox"/> Rescue Pole 27. <input type="checkbox"/> Life Ring 28. <input checked="" type="checkbox"/> Safety Signs 29. <input type="checkbox"/> First Aid Kit 30. <input type="checkbox"/> Chlorine Gas Safety	General Facilities 31. <input type="checkbox"/> Exterior Lighting 32. <input type="checkbox"/> Indoor Ventilation 33. <input type="checkbox"/> Restrooms & Toilets 34. <input type="checkbox"/> Handwash Sinks 35. <input type="checkbox"/> Dressing Rooms 36. <input type="checkbox"/> Showers 37. <input type="checkbox"/> Drinking Fountains Miscellaneous 38. <input type="checkbox"/> Chemical Test Kits 39. <input checked="" type="checkbox"/> Chemical Testing Frequency 40. <input checked="" type="checkbox"/> Record Keeping 41. <input type="checkbox"/> Lifeguards 42. <input type="checkbox"/> Communicable Disease Control 43. <input checked="" type="checkbox"/> Site Supervision & Control 44. <input type="checkbox"/> General Sanitation 45. <input checked="" type="checkbox"/> Other:
---	--	---

Comments:
**** POOL SHALL REMAIN CLOSED FOR THE FOLLOWING CRITICAL VIOLATIONS.**

~~ CRITICAL VIOLATIONS **~~**

(16) (17) MAINTAIN PROPER POOL CHEMISTRY AT ALL TIMES THE POOL IS OPEN. PH SHALL BE 7.2-7.8 AND FREE CHLORINE W/ CYANURIC ACID SHALL BE 2.0-10.0 PPM. POOL MEASURED NON-DETECT FOR FREE CHLORINE & >8.5 FOR pH.

(26) PROVIDE A RESCUE POLE AT THE POOLSIDE.

(28) PROVIDE A "KEEP GATE CLOSED" SIGN THAT IS CONSPICUOUS AND MOUNTED TO ENTRANCE GATE.

(39) POOL CHEMICALS FOR pH & CHLORINE SHALL BE TESTED DAILY & CYANURIC ACID MONTHLY.

(40) ALL CHEMICAL TESTING, AND OPERATION RECORDS SHALL BE DOCUMENTED AND AVAILABLE FOR INSPECTION AT ALL TIMES.

Received By: [Signature]	REHS: ANDREW PATEL
---------------------------------	---------------------------

OFFICIAL INSPECTION REPORT
Continuation Sheet
GLENN COUNTY ENVIRONMENTAL HEALTH DEPARTMENT
257 North Villa Avenue, Willows, CA 95988
Phone (530) 934-6102 FAX (530) 934-6103

Page 2 of 2

Name of Facility/ DBA: <u>BEST WESTERN Willows INN</u>	Inspection Date: <u>6/11/15</u>
Address: <u>PAGE 2</u>	
Owner/Permitee: <u>PAGE 2</u>	

Comments:

OTHER VIOLATIONS (CONT.)

13 THE GATE TO THE POOL ENCLOSURE SHALL BE KEPT CLOSED AT ALL TIMES. A OBSERVED GATE PROPEL OPEN W/ ROCK.

15 VARIABLE SPEED PUMP PROGRAM SHALL BE SUBMITTED AND APPROVED BY G.C.E.H.

Received By: <u>X Zuma mata</u>	REHS: <u>ANDREW P 12740</u>
---------------------------------	-----------------------------