

SWIMMING POOL OFFICIAL INSPECTION REPORT
 GLENN COUNTY HEALTH DEPARTMENT ENVIRONMENTAL HEALTH
 257 N. Villa Ave., Willows, CA 95988
 (530) 934-6102

BUSINESS ADDRESS 545 N Humboldt Ave, Willows, CA		DATE 5/12/15
OWNER'S NAME/DBA Holiday Inn Express Spa		COMPUTER NUMBER
MAILING ADDRESS S.A.D.		TIME IN 4:30pm
PERMIT/LICENSE	PROGRAM/ELEMENT Spa	SERVICE 002
RATE OF FLOW Not Measured		TIME OUT 5:00pm
pH 7.9	CL > 3.5 ppm	TEMP 104°F
OTHER		

EQUIPMENT CATEGORY	DESCRIPTION	STR	OPER	Remarks
		1-19	20-26	
RECIRCULATION EQUIPMENT	Filters	1	2	The marked items represent Health Code violations and must be corrected as follows: Spa is cleared to reopen for business Note: pH is still high at 7.5, but within measurable range (± 0.1) of 7-8. Note: Free Cl is above 7.0 ppm. Acceptable range is 3.0-10.0 ppm. Check to ensure Free Cl is not above 10.0 ppm.
	Pumps	3	4	
	Chlorinator	5	6	
	Flowmeter	7	8	
	Gauges	9	10	
	Skimmer & Gutters	11	12	
	Back Flow Prev.	13	14	
	Waste Water Prev.	15	16	
	Water Supply/Quality	17	18	
Pipe & Fittings	19			
CONSTRUCTION	Pool Shell		20	
	Bottom & Sides	21	22	
	Decking & Coping	23	24	
	Diving Boards	25	26	
SAFETY EQUIPMENT	Resure Pole	27	28	
	Life Rings	29	30	
	Safety Signs	31	32	
	Lifeguard		33	
	Lighting Elec.	34	35	
	Ladders	36	37	
	Depth Markers	38	39	
	First Aid Kits	40	41	
Gas Masks	42	43		
REST ROOMS	Showers	44	45	
	Toilet & Dressing	46	47	
	Ventilation	48	49	
POOL QUALITY	Chlorine		50	
	pH		51	
	Cyanurates		52	
	Clarity		53	
	Test Kits		54	
OTHER	Supervision & Control		55	
	General Sanitation		56	
	Miscellaneous		57	

POOL STATUS: (MARK ONE)

58 E
 59 G
 60 P
 61 F
 62 C

OFFICE ADDRESS AND PHONE NUMBER	RECEIVED BY: <i>[Signature]</i>
	SANITARIAN: John Wells
	PAGE 1 OF 1