

SWIMMING POOL OFFICIAL INSPECTION REPORT

GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988
Phone: (530) 934-6102 • Fax: (530) 934-6103

Page 1 of 1

Name of Facility/DBA: CEDAR HILLS MANOR POOL		Inspection Date: 6/13/17	
Address: 600 N. HUMBOLDT AVE, WILLOWS, CA		Reinspection Date (on or after): NEXT INSPECTION <small>(Reinspections are subject to fees)</small>	
Owner/Permittee: EUGENE J. WILLIAMS	Phone Number:	Inspection Time: 11:00	Permit Expiration Date:
Pool Type: <input checked="" type="checkbox"/> Swimming Pool <input type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other	Service: <input checked="" type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other		
pH: 7.3	Free Chlorine: 15.7 PPM	Combined Chlorine: NOT TESTED	Cyanuric Acid: 66 PPM
	Flow Rate: 60 GPM	Temperature: -	Other: -

Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20

Pool Construction

1. Pool Shell
2. Bottom & Sides
3. Decks & Coping
4. Diving Boards
5. Depth Markers
6. Ladders/Steps/Railings
7. Underwater Lighting & Electrical

Water Quality

16. pH
17. Chlorine/Bromine
18. Cyanuric Acid
19. Debris in Pool
20. Water Clarity
21. Temperature
22. Flow Rate/Turnover

General Facilities

31. Exterior Lighting
32. Indoor Ventilation
33. Restrooms & Toilets
34. Handwash Sinks
35. Dressing Rooms
36. Showers
37. Drinking Fountains

Recirculation Equipment

8. Filters
9. Pumps
10. Flowmeter
11. Pressure/Vacuum Gauges
12. Skimmers & Gutters
13. Pipes & Fittings
14. Chemical Feeders
15. Water Supply/Backflow Prevention

Safety Equipment

23. Gates/Enclosure
24. Drain Covers
25. Anti-Entrapment Shutoff
26. Rescue Pole
27. Life Ring
28. Safety Signs
29. First Aid Kit
30. Chlorine Gas Safety

Miscellaneous

38. Chemical Test Kits
39. Chemical Testing Frequency
40. Record Keeping
41. Lifeguards
42. Communicable Disease Control
43. Site Supervision & Control
44. General Sanitation
45. Other:

Comments:

- NO CRITICAL VIOLATIONS

OTHER VIOLATIONS

11. INSTALL A VACUUM GAUGE ON THE SUCTION SIDE OF THE POOL PLUMBING.
12. PROVIDE WEIRS IN THE SKIMMERS AT THE POOL.
14. REPAIR THE LEAK ON THE CHLORINE TABLET FEEDER.
23. REPAIR THE STRIKE PLATE ON THE POOL GATE. ONE SCREW IS MISSING. GATE STILL LATCHES & SELF CLOSES.
28. RE-PAINT THE NO DIVING SIGNS ON THE DECK OF THE POOL.

Received By: 

REHS: 