

SWIMMING POOL OFFICIAL INSPECTION REPORT

GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988
Phone: (530) 934-6102 • Fax: (530) 934-6103

Name of Facility/DBA: <u>VILLA COURT TOWNHOMES</u>		Inspection Date: <u>6/7/16</u>	
Address: <u>127 VILLA COURT, WILLOWS, CA 95988</u>		Reinspection Date (on or after): <u>NEXT INSPECTION</u> <small>(Reinspections are subject to fees)</small>	
Owner/Permittee: <u>VILLA COURT TOWNHOMES INVESTORS</u>		Phone Number:	Inspection Time: <u>12:30</u>
Permit Expiration Date:		Service: <input checked="" type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other	
Pool Type: <input checked="" type="checkbox"/> Swimming Pool <input type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool	pH: <u>7.1</u>		
<input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other	Free Chlorine: <u>~ 3.5 PPM</u>	Combined Chlorine: <u>NOT TESTED</u>	Cyanuric Acid: <u>~ 20 PPM</u>
	Flow Rate: <u>UNABLE TO TEST</u>	Temperature: <u>N/A</u>	Other: <u>-</u>

Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20

Pool Construction

1. Pool Shell
2. Bottom & Sides
3. Decks & Coping
4. Diving Boards
5. Depth Markers
6. Ladders/Steps/Railings
7. Underwater Lighting & Electrical

Water Quality

16. pH
17. Chlorine/Bromine
18. Cyanuric Acid
19. Debris in Pool
20. Water Clarity
21. Temperature
22. Flow Rate/Turnover

General Facilities

31. Exterior Lighting
32. Indoor Ventilation
33. Restrooms & Toilets
34. Handwash Sinks
35. Dressing Rooms
36. Showers
37. Drinking Fountains

Recirculation Equipment

8. Filters
9. Pumps
10. Flowmeter
11. Pressure/Vacuum Gauges
12. Skimmers & Gutters
13. Pipes & Fittings
14. Chemical Feeders
15. Water Supply/Backflow Prevention

Safety Equipment

23. Gates/Enclosure
24. Drain Covers
25. Anti-Entrapment Shutoff
26. Rescue Pole
27. Life Ring
28. Safety Signs
29. First Aid Kit
30. Chlorine Gas Safety

Miscellaneous

38. Chemical Test Kits
39. Chemical Testing Frequency
40. Record Keeping
41. Lifeguards
42. Communicable Disease Control
43. Site Supervision & Control
44. General Sanitation
45. Other:

Comments:

VIOLATIONS:

- ③ REPAIR DECKING AT THE DEEP END OF THE POOL SO THERE ISN'T ANY CRACKS & CREVICES.
- ⑧ BACKWASH / CLEAN THE FILTER SO THAT IT CAN FILTER EFFECTIVELY. WATER CLARITY WAS A LITTLE HAZY.
- ⑩ REPAIR / REPLACE THE FLOW METER SO THAT IT WORKS PROPERLY. REPEAT VIOLATION
- ⑩ INCREASE THE pH IN THE POOL SO THAT IT IS WITHIN RANGE 7.2-7.8
- ⑬ MAINTAIN PEST CONTROL IN POOL EQUIPMENT ROOM. OBSERVED BLACK WIDOW NEAR CHLORINE FEEDER.

Received By:

Karin Miller

REHS:

Andrew F. Fargo