

# SWIMMING POOL OFFICIAL INSPECTION REPORT

## GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988  
Phone: (530) 934-6102 • Fax: (530) 934-6103

Page 1 of 1

Name of Facility/DBA: <u>Villa Ct. Townhomes</u>		Inspection Date: <u>7/1/15</u>	
Address: <u>127 Villa Court, Willows, CA</u>		Reinspection Date (on or after): <u>NEXT INSPECTION</u> <small>(Reinspections are subject to fees)</small>	
Owner/Permittee: <u>Ferguson &amp; Brewer Maint.</u>	Phone Number: <u>877-1352</u>	Inspection Time: <u>11:00</u>	Permit Expiration Date:
Pool Type: <input checked="" type="checkbox"/> Swimming Pool <input type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other	Service: <input type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other		
pH: <u>7.5</u>	Free Chlorine: <u>8.5 ppm</u>	Combined Chlorine: <u>0.5</u>	Cyanuric Acid: <u>17 ppm</u>
		Flow Rate: <u>UNABLE TO TEST</u>	Temperature: <u>N/A</u>
			Other: <u>-</u>

*Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20*

<p><b>Pool Construction</b></p> <ol style="list-style-type: none"> <li>1. <input type="checkbox"/> Pool Shell</li> <li>2. <input type="checkbox"/> Bottom &amp; Sides</li> <li>3. <input checked="" type="checkbox"/> Decks &amp; Coping</li> <li>4. <input type="checkbox"/> Diving Boards</li> <li>5. <input type="checkbox"/> Depth Markers</li> <li>6. <input type="checkbox"/> Ladders/Steps/Railings</li> <li>7. <input type="checkbox"/> Underwater Lighting &amp; Electrical</li> </ol> <p><b>Recirculation Equipment</b></p> <ol style="list-style-type: none"> <li>8. <input type="checkbox"/> Filters</li> <li>9. <input type="checkbox"/> Pumps</li> <li>10. <input checked="" type="checkbox"/> Flowmeter</li> <li>11. <input type="checkbox"/> Pressure/Vacuum Gauges</li> <li>12. <input type="checkbox"/> Skimmers &amp; Gutters</li> <li>13. <input type="checkbox"/> Pipes &amp; Fittings</li> <li>14. <input type="checkbox"/> Chemical Feeders</li> <li>15. <input type="checkbox"/> Water Supply/Backflow Prevention</li> </ol>	<p><b>Water Quality</b></p> <ol style="list-style-type: none"> <li>16. <input type="checkbox"/> pH</li> <li>17. <input checked="" type="checkbox"/> Chlorine</li> <li>18. <input type="checkbox"/> Cyanuric Acid</li> <li>19. <input type="checkbox"/> Other Chemicals</li> <li>20. <input type="checkbox"/> Water Clarity</li> <li>21. <input type="checkbox"/> Temperature</li> <li>22. <input type="checkbox"/> Flow Rate/Turnover</li> </ol> <p><b>Safety Equipment</b></p> <ol style="list-style-type: none"> <li>23. <input type="checkbox"/> Gates/Enclosure</li> <li>24. <input type="checkbox"/> Drain Covers</li> <li>25. <input type="checkbox"/> Anti-Entrapment Shutoff</li> <li>26. <input type="checkbox"/> Rescue Pole</li> <li>27. <input type="checkbox"/> Life Ring</li> <li>28. <input checked="" type="checkbox"/> Safety Signs</li> <li>29. <input type="checkbox"/> First Aid Kit</li> <li>30. <input type="checkbox"/> Chlorine Gas Safety</li> </ol>	<p><b>General Facilities</b></p> <ol style="list-style-type: none"> <li>31. <input type="checkbox"/> Exterior Lighting</li> <li>32. <input type="checkbox"/> Indoor Ventilation</li> <li>33. <input type="checkbox"/> Restrooms &amp; Toilets</li> <li>34. <input type="checkbox"/> Handwash Sinks</li> <li>35. <input type="checkbox"/> Dressing Rooms</li> <li>36. <input type="checkbox"/> Showers</li> <li>37. <input type="checkbox"/> Drinking Fountains</li> </ol> <p><b>Miscellaneous</b></p> <ol style="list-style-type: none"> <li>38. <input type="checkbox"/> Chemical Test Kits</li> <li>39. <input type="checkbox"/> Chemical Testing Frequency</li> <li>40. <input checked="" type="checkbox"/> Record Keeping</li> <li>41. <input type="checkbox"/> Lifeguards</li> <li>42. <input type="checkbox"/> Communicable Disease Control</li> <li>43. <input type="checkbox"/> Site Supervision &amp; Control</li> <li>44. <input type="checkbox"/> General Sanitation</li> <li>45. <input type="checkbox"/> Other:</li> </ol>
--	---	---

Comments:

VIOLATIONS:

(3) REPAIR SHARP CRACKS ALONG THE DECKING AT THE DEEP END OF THE POOL.

(10) REPAIR/REPLACE THE FLOW METER ON THE POOL PLUMBING, SO THAT FLOW CAN BE DETERMINED.

(17) MAINTAIN COMBINED CHLORINE AT LESS THAN 0.4 PPM. POOL MEASURED 0.5 PPM.

(28) PROVIDE SAFETY SIGNS AT THE POOL INDICATING POOL CAPACITY & THE REQUIRED DARRHEA INFORMATION (SEE ATTACHED).

(40) RECORD POOL CHEMICAL READINGS FOR pH & CHLORINE DAILY AND CYANURIC ACID ONCE A MONTH. POOL RECORDS WERE MISSING, CYANURIC & LAST TWO DAYS OF MEASUREMENTS.

Received By: <u>[Signature]</u>	REHS: <u>[Signature]</u>
---------------------------------	--------------------------