

SWIMMING POOL OFFICIAL INSPECTION REPORT

GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988
Phone: (530) 934-6102 • Fax: (530) 934-6103

Page 1 of 1

Name of Facility/DBA: <u>Tierra Del Sol Apartments Pool</u>		Inspection Date: <u>7/7/15</u>	
Address: <u>73 E. Walker St, Orland, CA 95963</u>		Reinspection Date (on or after): <u>By Appointment</u> <small>(Reinspections are subject to fees)</small>	
Owner/Permittee: <u>Robert Howard</u>	Phone Number: <u>204-8126</u>	Inspection Time: <u>4:05pm</u>	Permit Expiration Date:
Pool Type: <input checked="" type="checkbox"/> Swimming Pool <input type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other	Service: <input checked="" type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other		
pH: <u>7.4</u>	Free Chlorine: <u>1.2 ppm</u>	Combined Chlorine: <u>0.5 ppm</u>	Cyanuric Acid: <u>55 ppm</u>
		Flow Rate: <u>could not determine</u>	Temperature: <u>83 ppm</u>
Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20			

Pool Construction 1. <input type="checkbox"/> Pool Shell 2. <input type="checkbox"/> Bottom & Sides 3. <input type="checkbox"/> Decks & Coping 4. <input type="checkbox"/> Diving Boards 5. <input type="checkbox"/> Depth Markers 6. <input type="checkbox"/> Ladders/Steps/Railings 7. <input type="checkbox"/> Underwater Lighting & Electrical Recirculation Equipment 8. <input type="checkbox"/> Filters 9. <input type="checkbox"/> Pumps 10. <input checked="" type="checkbox"/> Flowmeter 11. <input type="checkbox"/> Pressure/Vacuum Gauges 12. <input type="checkbox"/> Skimmers & Gutters 13. <input type="checkbox"/> Pipes & Fittings 14. <input type="checkbox"/> Chemical Feeders 15. <input type="checkbox"/> Water Supply/Backflow Prevention	Water Quality 16. <input type="checkbox"/> pH 17. <input checked="" type="checkbox"/> Chlorine 18. <input type="checkbox"/> Cyanuric Acid 19. <input type="checkbox"/> Other Chemicals 20. <input checked="" type="checkbox"/> Water Clarity 21. <input type="checkbox"/> Temperature 22. <input type="checkbox"/> Flow Rate/Turnover Safety Equipment 23. <input type="checkbox"/> Gates/Enclosure 24. <input type="checkbox"/> Drain Covers 25. <input type="checkbox"/> Anti-Entrapment Shutoff 26. <input type="checkbox"/> Rescue Pole 27. <input type="checkbox"/> Life Ring 28. <input checked="" type="checkbox"/> Safety Signs 29. <input type="checkbox"/> First Aid Kit 30. <input type="checkbox"/> Chlorine Gas Safety	General Facilities 31. <input type="checkbox"/> Exterior Lighting 32. <input type="checkbox"/> Indoor Ventilation 33. <input type="checkbox"/> Restrooms & Toilets 34. <input type="checkbox"/> Handwash Sinks 35. <input type="checkbox"/> Dressing Rooms 36. <input type="checkbox"/> Showers 37. <input type="checkbox"/> Drinking Fountains Miscellaneous 38. <input type="checkbox"/> Chemical Test Kits 39. <input type="checkbox"/> Chemical Testing Frequency 40. <input type="checkbox"/> Record Keeping 41. <input type="checkbox"/> Lifeguards 42. <input type="checkbox"/> Communicable Disease Control 43. <input type="checkbox"/> Site Supervision & Control 44. <input checked="" type="checkbox"/> General Sanitation 45. <input type="checkbox"/> Other:
--	---	--

Comments:
 * Pool is closed! Do not reopen without approval from our Department.

* Critical Violations (Closure violations)

17a) Maintain Free chlorine between 2.0 - 10.0 ppm. Measured 1.2 ppm of free chlorine.

20) Maintain pool water clear so main drain is easily visible from deck - Pool water had white cloudiness & main drain was not visible from shallow end of pool.

* Other Violations

10) Repair/replace inoperable flow meter.

17) Reduce combined chlorine to 0.4 ppm or less. Measured 0.5 ppm.

28) Provide graphic "no diving" sign adjacent to depth markers on deck.

4A) Clean bees & other bugs from skimmer.

Received By: <u>[Signature]</u>	REHS: <u>John H. Wells</u>
---------------------------------	----------------------------