

SWIMMING POOL OFFICIAL INSPECTION REPORT

GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988
Phone: (530) 934-6102 • Fax: (530) 934-6103

Page 1 of 1

Name of Facility/DBA: <i>Willows Springs Senior Apts.</i>		Inspection Date: <i>9/13/16</i>	
Address: <i>1340 W. SYCAMORE ST., WILLOWS, CA</i>		Reinspection Date (on or after): <i>*POOL IS CLOSED</i> <small>(Reinspections are subject to fees)</small>	
Owner/Permittee: <i>Willows Pacific Assoc. CALP</i>	Phone Number: <i>934-3411</i>	Inspection Time: <i>10:00</i>	Permit Expiration Date:
Pool Type: <input checked="" type="checkbox"/> Swimming Pool <input type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other	Service: <input checked="" type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other		
pH: <i>7.5</i>	Free Chlorine: <i>~ 0.2 PPM</i>	Combined Chlorine: <i>NOT TESTED</i>	Cyanuric Acid: <i>~ 9 PPM</i>
Flow Rate: <i>85 GPM</i>	Temperature: <i>NOT TESTED</i>	Other: <i>-</i>	

Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20

Pool Construction	Water Quality	General Facilities
1. <input type="checkbox"/> Pool Shell	16. <input type="checkbox"/> pH	31. <input type="checkbox"/> Exterior Lighting
2. <input type="checkbox"/> Bottom & Sides	17. <input checked="" type="checkbox"/> Chlorine/Bromine	32. <input type="checkbox"/> Indoor Ventilation
3. <input checked="" type="checkbox"/> Decks & Coping	18. <input type="checkbox"/> Cyanuric Acid	33. <input type="checkbox"/> Restrooms & Toilets
4. <input type="checkbox"/> Diving Boards	19. <input type="checkbox"/> Debris in Pool	34. <input type="checkbox"/> Handwash Sinks
5. <input type="checkbox"/> Depth Markers	20. <input type="checkbox"/> Water Clarity	35. <input type="checkbox"/> Dressing Rooms
6. <input type="checkbox"/> Ladders/Steps/Railings	21. <input type="checkbox"/> Temperature	36. <input type="checkbox"/> Showers
7. <input type="checkbox"/> Underwater Lighting & Electrical	22. <input type="checkbox"/> Flow Rate/Turnover	37. <input type="checkbox"/> Drinking Fountains
Recirculation Equipment	Safety Equipment	Miscellaneous
8. <input checked="" type="checkbox"/> Filters	23. <input type="checkbox"/> Gates/Enclosure	38. <input type="checkbox"/> Chemical Test Kits
9. <input type="checkbox"/> Pumps	24. <input type="checkbox"/> Drain Covers	39. <input type="checkbox"/> Chemical Testing Frequency
10. <input type="checkbox"/> Flowmeter	25. <input type="checkbox"/> Anti-Entrapment Shutoff	40. <input type="checkbox"/> Record Keeping
11. <input type="checkbox"/> Pressure/Vacuum Gauges	26. <input type="checkbox"/> Rescue Pole	41. <input type="checkbox"/> Lifeguards
12. <input type="checkbox"/> Skimmers & Gutters	27. <input type="checkbox"/> Life Ring	42. <input type="checkbox"/> Communicable Disease Control
13. <input type="checkbox"/> Pipes & Fittings	28. <input checked="" type="checkbox"/> Safety Signs	43. <input type="checkbox"/> Site Supervision & Control
14. <input type="checkbox"/> Chemical Feeders	29. <input type="checkbox"/> First Aid Kit	44. <input type="checkbox"/> General Sanitation
15. <input type="checkbox"/> Water Supply/Backflow Prevention	30. <input type="checkbox"/> Chlorine Gas Safety	45. <input checked="" type="checkbox"/> Other:

Comments:

*** POOL IS CLOSED ON THE ABOVE DATE & TIME FOR THE FOLLOWING VIOLATIONS OF THE CALIFORNIA HEALTH & SAFETY CODE:*

*** CRITICAL VIOLATIONS ***

(17) MAINTAIN POOL SANITIZER (FREE CHLORINE) AT OR ABOVE 2.0 PPM AND LESS THAN 10 PPM AT ALL TIMES POOL IS OPEN. POOL MEASURED < 0.2 PPM.

VIOLATIONS

(3) REPAIR POOL COPING SO THAT IT IS FLUSH WITH THE DECK. COPING HAS SEPERATED FROM THE DECK.

(8) BACKWASH / CLEAN THE DIRTY FILTER IN THE POOL ROOM.

(28) PROVIDE LEGIBLE SAFETY SIGNS THAT INDICATE POOL CAPACITY & HOURS.

(45) UNABLE TO INSPECT POOL RECORDS AS THEY WERE NOT AVAILABLE DURING TIME OF INSPECTION.

Received By: <i>U.S. MAIL</i>	REHS: <i>ANDREW PEYO</i>
-------------------------------	--------------------------