

# SWIMMING POOL OFFICIAL INSPECTION REPORT

## GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988  
Phone: (530) 934-6102 • Fax: (530) 934-6103

Page 1 of 1

Name of Facility/DBA: <u>DOLPHIN CLUB POOL</u>		Inspection Date: <u>9/15/16</u>	
Address: <u>233 W. 1<sup>ST</sup> AVE, WILLOWS, CA</u>		Reinspection Date (on or after): <u>NEXT INSPECTION</u> <small>(Reinspections are subject to fees)</small>	
Owner/Permittee:		Phone Number:	Inspection Time: Permit Expiration Date:
Pool Type: <input checked="" type="checkbox"/> Swimming Pool <input type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other		Service: <input checked="" type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other	
pH: <u>7.6</u>	Free Chlorine: <u>1.5.1 PPM</u>	Combined Chlorine: <u>NOT TESTED</u>	Cyanuric Acid: <u>N20 PPM</u>
Flow Rate: <u>80 GPM</u>		Temperature: <u>—</u>	Other: <u>—</u>

*Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20*

<b>Pool Construction</b> 1. <input checked="" type="checkbox"/> Pool Shell 2. <input type="checkbox"/> Bottom & Sides 3. <input type="checkbox"/> Decks & Coping 4. <input type="checkbox"/> Diving Boards 5. <input type="checkbox"/> Depth Markers 6. <input type="checkbox"/> Ladders/Steps/Railings 7. <input type="checkbox"/> Underwater Lighting & Electrical	<b>Water Quality</b> 16. <input type="checkbox"/> pH 17. <input type="checkbox"/> Chlorine/Bromine 18. <input type="checkbox"/> Cyanuric Acid 19. <input type="checkbox"/> Debris in Pool 20. <input type="checkbox"/> Water Clarity 21. <input type="checkbox"/> Temperature 22. <input type="checkbox"/> Flow Rate/Turnover	<b>General Facilities</b> 31. <input type="checkbox"/> Exterior Lighting 32. <input type="checkbox"/> Indoor Ventilation 33. <input type="checkbox"/> Restrooms & Toilets 34. <input type="checkbox"/> Handwash Sinks 35. <input type="checkbox"/> Dressing Rooms 36. <input checked="" type="checkbox"/> Showers 37. <input type="checkbox"/> Drinking Fountains
<b>Recirculation Equipment</b> 8. <input type="checkbox"/> Filters 9. <input type="checkbox"/> Pumps 10. <input checked="" type="checkbox"/> Flowmeter 11. <input type="checkbox"/> Pressure/Vacuum Gauges 12. <input type="checkbox"/> Skimmers & Gutters 13. <input type="checkbox"/> Pipes & Fittings 14. <input type="checkbox"/> Chemical Feeders 15. <input checked="" type="checkbox"/> Water Supply/Backflow Prevention	<b>Safety Equipment</b> 23. <input type="checkbox"/> Gates/Enclosure 24. <input type="checkbox"/> Drain Covers 25. <input type="checkbox"/> Anti-Entrapment Shutoff 26. <input type="checkbox"/> Rescue Pole 27. <input checked="" type="checkbox"/> Life Ring <u>AP</u> 28. <input type="checkbox"/> Safety Signs 29. <input type="checkbox"/> First Aid Kit 30. <input type="checkbox"/> Chlorine Gas Safety	<b>Miscellaneous</b> 38. <input type="checkbox"/> Chemical Test Kits 39. <input checked="" type="checkbox"/> Chemical Testing Frequency 40. <input checked="" type="checkbox"/> Record Keeping 41. <input type="checkbox"/> Lifeguards 42. <input type="checkbox"/> Communicable Disease Control 43. <input type="checkbox"/> Site Supervision & Control 44. <input type="checkbox"/> General Sanitation 45. <input checked="" type="checkbox"/> Other:

Comments: VIOLATIONS:

① CLEAN/WASH/RE-FINISH THE POOL SHELL AS IT HAS SIGNIFICANT ALGAE GROWTH ALONG THE SHELL.

⑩ REPAIR/REPLACE THE FLOW METER IN THE POOL GIRL ROOM.

⑮ PROVIDE A BACKFLOW PREVENTION DEVICE ON ALL THE SPIGOTS AROUND THE POOL.

⑳ REPAIR/REPLACE THE POOL SHOWER. IT HAS FALLEN INTO DIS-REPAIR. THE HOSE IS COMPLETELY DIS-CONNECTED

⑳+㉑ RECORD & TEST pH & FREE CHLORINE LEVEL ON A DAILY BASIS

㉕ MARK & DISPLAY THE DIRECTION OF FLOW ON THE PLUMBING.

Received By: X [Signature] REHS: ANDREW PETYO [Signature]