

SWIMMING POOL OFFICIAL INSPECTION REPORT

GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988

Phone: (530) 934-6102 • Fax: (530) 934-6103

Page 1 of 1

Name of Facility/DBA: CEDAR HILLS MANOR POOL				Inspection Date: 6/27/18			
Address: 600 N. HUMBOLDT AVE, WILLOWS, CA				Reinspection Date (on or after): * POOL IS CLOSED <small>(Reinspections are subject to fees)</small>			
Owner/Permittee: EUGENE J. WILLIAMS			Phone Number:		Inspection Time: 3:30		Permit Expiration Date:
Pool Type: <input checked="" type="checkbox"/> Swimming Pool <input type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other				Service: <input checked="" type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other			
pH: 6.9	Free Chlorine: ~ 1.1 PPM	Combined Chlorine: NOT TESTED	Cyanuric Acid: 255 PPM	Flow Rate: 90 GPM	Temperature: -	Other: -	
Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20							

Pool Construction 1. <input type="checkbox"/> Pool Shell 2. <input type="checkbox"/> Bottom & Sides 3. <input type="checkbox"/> Decks & Coping 4. <input type="checkbox"/> Diving Boards 5. <input type="checkbox"/> Depth Markers 6. <input type="checkbox"/> Ladders/Steps/Railings 7. <input type="checkbox"/> Underwater Lighting & Electrical	Water Quality 16. <input checked="" type="checkbox"/> pH 17. <input checked="" type="checkbox"/> Chlorine/Bromine 18. <input type="checkbox"/> Cyanuric Acid 19. <input type="checkbox"/> Debris in Pool 20. <input type="checkbox"/> Water Clarity 21. <input type="checkbox"/> Temperature 22. <input type="checkbox"/> Flow Rate/Turnover	General Facilities 31. <input type="checkbox"/> Exterior Lighting 32. <input type="checkbox"/> Indoor Ventilation 33. <input type="checkbox"/> Restrooms & Toilets 34. <input type="checkbox"/> Handwash Sinks 35. <input type="checkbox"/> Dressing Rooms 36. <input type="checkbox"/> Showers 37. <input type="checkbox"/> Drinking Fountains
Recirculation Equipment 8. <input type="checkbox"/> Filters 9. <input type="checkbox"/> Pumps 10. <input type="checkbox"/> Flowmeter 11. <input type="checkbox"/> Pressure/Vacuum Gauges 12. <input checked="" type="checkbox"/> Skimmers & Gutters 13. <input type="checkbox"/> Pipes & Fittings 14. <input type="checkbox"/> Chemical Feeders 15. <input type="checkbox"/> Water Supply/Backflow Prevention	Safety Equipment 23. <input type="checkbox"/> Gates/Enclosure 24. <input type="checkbox"/> Drain Covers 25. <input type="checkbox"/> Anti-Entrapment Shutoff 26. <input type="checkbox"/> Rescue Pole 27. <input type="checkbox"/> Life Ring 28. <input checked="" type="checkbox"/> Safety Signs 29. <input type="checkbox"/> First Aid Kit 30. <input type="checkbox"/> Chlorine Gas Safety	Miscellaneous 38. <input type="checkbox"/> Chemical Test Kits 39. <input type="checkbox"/> Chemical Testing Frequency 40. <input type="checkbox"/> Record Keeping 41. <input type="checkbox"/> Lifeguards 42. <input type="checkbox"/> Communicable Disease Control 43. <input type="checkbox"/> Site Supervision & Control 44. <input type="checkbox"/> General Sanitation 45. <input checked="" type="checkbox"/> Other:

Comments:

**** POOL IS CLOSED ON THE ABOVE DATE & TIME FOR THE FOLLOWING CRITICAL VIOLATIONS:**

**** CRITICAL VIOLATIONS ****

(12) REPAIR WEIRS IN BOTH SKIMMERS. WEIRS HAVE BECOME DETACHED AND FLOATING AROUND.

(16) MAINTAIN POOL pH BETWEEN 7.2 - 7.8. POOL MEASURED 6.9.

(17) MAINTAIN POOL FREE AVAILABLE CHLORINE (FCL) ABOVE 2.0 AND BELOW 10.00 PPM. 2 FCL MEASURED ONLY 1.1 PPM

OTHER VIOLATIONS

(28) OBTAIN "NEW" DIARRHEA SIGN WITH UPDATED WORDING.

(45) RE-PAINT THE "NO DIVING" SIGNS ON THE DECK OF THE POOL, THEY HAVE ~~BE~~ ARE VERY FADED.

Received By:	REHS: ANDREW PERRO
--------------	---------------------------