

SWIMMING POOL OFFICIAL INSPECTION REPORT

GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988

Phone: (530) 934-6102 • Fax: (530) 934-6103

Page 1 of 1

Name of Facility/DBA: <u>Willows Century Pool, Inc.</u>				Inspection Date: <u>9/6/18</u>	
Address: <u>551 WASHINGTON ST., WILLIAMS, CA 95988</u>				Reinspection Date (on or after): <u>NEXT INSPECTION</u> <small>(Reinspections are subject to fees)</small>	
Owner/Permittee: <u>Willows Century Pool Inc.</u>		Phone Number: <u>867-6482</u>		Inspection Time: <u>9:00</u>	Permit Expiration Date:
Pool Type: <input checked="" type="checkbox"/> Swimming Pool <input type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other		Service: <input checked="" type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other			
pH: <u>7.8</u>	Free Chlorine: <u>~ 5.7</u>	Combined Chlorine: <u>NOT TESTED</u>	Cyanuric Acid: <u>~ 32 PPM</u>	Flow Rate: <u>122 GPM</u>	Temperature: <u>—</u>
Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20					

Pool Construction 1. <input type="checkbox"/> Pool Shell 2. <input type="checkbox"/> Bottom & Sides 3. <input checked="" type="checkbox"/> Decks & Coping 4. <input type="checkbox"/> Diving Boards 5. <input type="checkbox"/> Depth Markers 6. <input type="checkbox"/> Ladders/Steps/Railings 7. <input type="checkbox"/> Underwater Lighting & Electrical	Water Quality 16. <input type="checkbox"/> pH 17. <input type="checkbox"/> Chlorine/Bromine 18. <input type="checkbox"/> Cyanuric Acid 19. <input type="checkbox"/> Debris in Pool 20. <input type="checkbox"/> Water Clarity 21. <input type="checkbox"/> Temperature 22. <input checked="" type="checkbox"/> Flow Rate/Turnover	General Facilities 31. <input type="checkbox"/> Exterior Lighting 32. <input type="checkbox"/> Indoor Ventilation 33. <input type="checkbox"/> Restrooms & Toilets 34. <input type="checkbox"/> Handwash Sinks 35. <input type="checkbox"/> Dressing Rooms 36. <input type="checkbox"/> Showers 37. <input type="checkbox"/> Drinking Fountains
Recirculation Equipment 8. <input type="checkbox"/> Filters 9. <input type="checkbox"/> Pumps 10. <input checked="" type="checkbox"/> Flowmeter 11. <input type="checkbox"/> Pressure/Vacuum Gauges 12. <input type="checkbox"/> Skimmers & Gutters 13. <input type="checkbox"/> Pipes & Fittings 14. <input type="checkbox"/> Chemical Feeders 15. <input type="checkbox"/> Water Supply/Backflow Prevention	Safety Equipment 23. <input type="checkbox"/> Gates/Enclosure 24. <input type="checkbox"/> Drain Covers 25. <input type="checkbox"/> Anti-Entrapment Shutoff 26. <input type="checkbox"/> Rescue Pole 27. <input type="checkbox"/> Life Ring 28. <input checked="" type="checkbox"/> Safety Signs 29. <input type="checkbox"/> First Aid Kit 30. <input type="checkbox"/> Chlorine Gas Safety	Miscellaneous 38. <input type="checkbox"/> Chemical Test Kits 39. <input type="checkbox"/> Chemical Testing Frequency 40. <input type="checkbox"/> Record Keeping 41. <input type="checkbox"/> Lifeguards 42. <input type="checkbox"/> Communicable Disease Control 43. <input type="checkbox"/> Site Supervision & Control 44. <input type="checkbox"/> General Sanitation 45. <input type="checkbox"/> Other:

Comments:

VIOLATIONS

③ REPAIR CRACKS & MISSING GROUT ALONG THE DECK & COPING ON THE POOL.

⑩ REPAIR/REPLACE FLOW METER ON NORTH SIDE RETURN PLUMBING.

②② MAINTAIN THE PROPER POOL TURNOVER RATE. POOL DID NOT MEET REQUIRED TURNOVER RATE. WE RECOMMEND PLANNING/MAKING IMPROVEMENTS TO POOL INFRASTRUCTURE TO MEET TURNOVER TIMES.

VACUUM = 10.5 inHg

$$\text{POOL VOL} = 65,910 \text{ i.} \quad \frac{65,910 \text{ i.}}{(122 \text{ GPM}) (60 \text{ MIN})} = 9 \text{ HR}$$

PSI = 14 PSI

CURRENT PUMP: INTELLIFLO VST. SVRS (LABEL PUMP 2)

~~②⑧ REPLACE UN-READABLE DIAPHRAGM SIGN ON THE FENCE. THE TEXT HAS WORN AWAY. (COS) (AP)~~

Received By: Rony Spear REHS: Andrew Perry