

OFFICIAL INSPECTION REPORT

Continuation Sheet

GLENN COUNTY ENVIRONMENTAL HEALTH DEPARTMENT

257 North Villa Avenue, Willows, CA 95988

Phone (530) 934-6102 FAX (530) 934-6103

Page 2 of 2

Name of Facility/ DBA: ELK'S LODGE	Inspection Date: 11/3/15
Address: PAGE 2	
Owner/Permittee: PAGE 2	

Comments:

** CRITICAL VIOLATIONS (CONT.) **

23) RODENT ENTRY POINTS. (HOLES IN THE WALL). REMOVE ALL UTENSILS & CLEAN/SANITIZE. CONTACT PEST CONTROL



35) REPLACE ALL NON-COMMERCIAL APPLIANCES WITH COMMERCIAL GRADE, N.S.F & HEALTH DEPT APPROVED ONES WHEN THEY FALL INTO DISREPAIR OR NO LONGER HOLD TEMP. (PANASONIC BLACK M-WAVE, CROCK POTS, HOUSEHOLD FREEZER)

35) CLEAN/SANITIZE THE INSIDE OF THE ICE MACHINE. OBSERVED PINK MOLD GROWING INSIDE

36) SECURE ALL PRESSURIZED CYLINDERS TO AN IMMOBILE SURFACE. CO2 CANISTERS IN BACK UN-SECURED.

41) ELEVATE INDIRECT PIPES UNDER BAR AREA SO THAT A ONE INCH AIR GAP BETWEEN PIPE AND THE TOP OF THE FLOOR DRAIN EXISTS.

41) SEAL UP WALL IN CUPBOARD NEXT TO 3-COMP SINK, THIS IS A RODENT ENTRY POINT

Received By: 	REHS: 
--------------------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------