SWIMMING POOL OFFICIAL INSPECTION REPORT

GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988
Phone: (530) 934-6102 • Fax: (530) 934-6103

Name of Facility/DBA:				Inspection Date:	
Pairgewood Apartments Pool				5/19/16	
Address:				Reinspection Date (on or after):	
745 Pairgewood Dr, Orland CA 95963				– (Reinspections are subject to fees)	
Owner/Permittee:		Phone Number:		Inspection Time:	Permit Expiration Date:
Orland Pacific Associates		(559) 805-8998		11:00 am	
Pool Type: ☒ Swimming Pool ☐ Spa Pool ☐ Wading Pool ☐ Interactive Water Feature ☐ Other		Service: ☐ Routine Inspection ☐ Reinspection ☐ Complaint ☐ Construction/Pre-Opening ☒ Other Spring Pool open			
pH:	Free Chlorine:	Combined Chlorine:	Cyanuric Acid:	Flow Rate:	Temperature:	Other:
7.2	4.1 ppm	0.4 ppm	45 ppm	–	–	Talk - 30 ppm CaHd - 133 ppm

Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20

Pool Construction	**Water Quality**	**General Facilities**
1. ☐ Pool Shell	16. ☐ pH	31. ☐ Exterior Lighting
2. ☐ Bottom & Sides	17. ☐ Chlorine/Bromine	32. ☐ Indoor Ventilation
3. ☐ Decks & Coping	18. ☐ Cyanuric Acid	33. ☐ Restrooms & Toilets
4. ☐ Diving Boards	19. ☐ Debris in Pool	34. ☐ Handwash Sinks
5. ☐ Depth Markers	20. ☐ Water Clarity	35. ☐ Dressing Rooms
6. ☐ Ladders/Steps/Railings	21. ☐ Temperature	36. ☐ Showers
7. ☐ Underwater Lighting & Electrical	22. ☐ Flow Rate/Turnover	37. ☐ Drinking Fountains
Recirculation Equipment	**Safety Equipment**	**Miscellaneous**
8. ☐ Filters	23. ☐ Gates/Enclosure	38. ☐ Chemical Test Kits
9. ☐ Pumps	24. ☐ Drain Covers	39. ☐ Chemical Testing Frequency
10. ☐ Flowmeter	25. ☐ Anti-Entrapment Shutoff	40. ☐ Record Keeping
11. ☐ Pressure/Vacuum Gauges	26. ☐ Rescue Pole	41. ☐ Lifeguards
12. ☐ Skimmers & Gutters	27. ☐ Life Ring	42. ☐ Communicable Disease Control
13. ☐ Pipes & Fittings	28. ☐ Safety Signs	43. ☐ Site Supervision & Control
14. ☐ Chemical Feeders	29. ☐ First Aid Kit	44. ☐ General Sanitation
15. ☐ Water Supply/Backflow Prevention	30. ☐ Chlorine Gas Safety	45. ☐ Other:

Comments:

Pool is cleared to open for spring/summer.

Recommendations

- adjust Total alkalinity to 80-120 ppm (measured 30)
- adjust calcium hardness to 200-400 ppm (measured 133)

Received By: Sharon Reed

REHS: John H. Wells