



Public Pool Operation Records

Glenn County Environmental Health
 225 N. Tehama Street, Willows, CA. 95988
 (530) 934-6102 Fax (530) 934-6103

**KEEP ALL FORMS &
 RECORDS FOR AT LEAST
 2 YEARS**

- **Disinfectant** (chlorine, bromine, other)—test daily
- **pH**—test daily
- **CYA** (cyanuric acid) - if used, test monthly

Pool Facility:	
Street Address, City, State and Zip Code:	
Owner:	
Pool Operator:	Telephone No.:
Classification (circle one): (a) Swimming pool (b) Spa (c) Wading (e) Other: _____	

Date	Time	Disinfectant	pH	CYA Cyanuric Acid	Water Clarity	Heated Pool or Spa Temp.	<u>Maintenance</u> <ul style="list-style-type: none"> • Indicate descriptions of routine maintenance, repairs, and corrective actions. • For additional comments, provide a continuation sheet.
		See Disinfection Chart	Min. 7.2 Max. 7.8	Max. 100 ppm	Bottom of deep end visible from deck (indicate Yes or No)	Max. 104° F	
							COMMENTS: _____ _____
							COMMENTS: _____ _____
							COMMENTS: _____ _____
							COMMENTS: _____ _____
							COMMENTS: _____ _____
							COMMENTS: _____ _____
							COMMENTS: _____ _____
							COMMENTS: _____ _____
							COMMENTS: _____ _____

DISINFECTION

	Free-Chlorine Residual				Bromine Residual	
	Without CYA		With CYA		Min	Max
	Min	Max	Min	Max		
Public Pools	1.0 ppm*	10.0 ppm*	2.0 ppm*	10.0 ppm*	2.0 ppm*	=
Public Spas, Wading Pools, and Spray Grounds	3.0 ppm	10.0 ppm	3.0 ppm	10.0 ppm	4.0 ppm	=

WATER CHARACTERISTICS CHART

	Minimum	Maximum
pH	7.2	7.8
Cyanuric Acid Concentration	0.0 ppm	100 ppm
Water Temperature	N/A	104° F

CHEMICAL CONTROL MONITORING & AUTOMATION

- ◆ With maintenance, calibration, and proper use in accordance with the manufacturer's directions, test sampling can be performed with automated chemical control systems. Written daily test results, equipment readings, calibrations, and corrective actions must be maintained by the pool operator.
- ◆ Prior to installing equipment, contact Glenn County Environmental Health at 530-934-6102.

